

Heat Integration using Pinch Analysis of Ammonia Plant



Submitted By:

| | |
|-----------------------|---------------------------------|
| Maqbool Khalid | NUST201433602BSCME99114F |
| Sumiah Naveed | NUST201432289BSCME99114F |
| Mohammad Talal | NUST201305235BSCME99113F |

Supervised By:


Dr. Arshad Hussain

**School of Chemical and Materials Engineering
(SCME)**

**National University of Science and Technology
(NUST)**

May, 2018

Heat Integration using Pinch Analysis of Ammonia Plant



Submitted By:

Maqbool Khalid

NUST201433602BSCME99114F

Sumiah Naveed

NUST201432289BSCME99114F

Mohammad Talal

NUST201305235BSCME99113F

**This report is submitted as a FYP thesis in partial
fulfilment of the requirement for the degree of
BE Chemical Engineering**

Supervisor: Dr. Arshad Hussain

Industrial Supervisor: Mr. Tehseen Ullah Khan

School of Chemical and Materials Engineering (SCME)

National University of Science and Technology (NUST)

May, 2018

Certificate

This is to certify that work in this thesis has been carried out by **Mr. Maqbool Khalid, Miss Sumiah Naveed and Mr. Mohammad Talal** and completed under my supervision in School of Chemical and Materials Engineering, National University of Sciences and Technology, H-12, Islamabad, Pakistan.

Supervisor: _____

Dr. Arshad Hussain

Principal/Dean SCME

Chemical Engineering Department

School of Chemical & Materials Engineering (SCME)

National University of Sciences and Technology (NUST), Islamabad

Submitted through:

HoD

Dr. Bilal Khan Niazi

Chemical Engineering

Department

School of Chemical & Materials

Engineering

National University of Sciences

and

Technology, Islamabad

Principal/ Dean

Dr. Arshad Hussain

School of Chemical & Materials

Engineering

National University of Sciences

and

Technology, Islamabad

Dedication

We dedicate our work to our parents and teachers, who helped us constantly to reach this point in our lives, and to Lt Col Retd. Nadeem Ehsan and Dr. Muhammad Nouman Aslam Khan for continuous support and love that they bestowed upon us.

Acknowledgements

Thanks to **Almighty Allah** for His countless blessings, He gave us courage to finish this project.

A very special recognition to our Dean, **Dr. Arshad Hussain** for supervising this project and for his support us throughout the year. Because of his experience and knowledge we are able to complete this project.

We express our profound gratitude to **Mr. Muhammad Farooq**, for giving us this project and believing in us.

Furthermore, we extend our gratitude to **Mr. Tehseen Ullah Khan** for his continual provision and guidance. He has been an immense source of assistance. We couldn't have completed all the necessary paperwork and delivered it properly without him.

We are able to achieve this milestone due to love and prayers of our beloved **parents**.

Nomenclature

| | |
|------------------|-----------------------------------|
| ΔT_{LM} | Log Mean Temperature Difference |
| T | Temperature |
| ΔT_{min} | Minimum Temperature Difference |
| ΔT | Temperature Difference |
| T_S | Supply Temperature |
| T_T | Target Temperature |
| c_p | Specific Heat Capacity |
| C_P | Heat Capacity |
| M | Mass Flowrate |
| Q | Heat |
| W | Work |
| ΔH | Change in Enthalpy |
| h | Heat Transfer Coefficient |
| U | Overall Heat Transfer Coefficient |
| A | Area |
| Wt% | Weight Percentage |
| L | Length of Coil |

| | |
|--------------------|----------------------------|
| p | Pitch of coil |
| R | Helix Radius |
| d_o | Coil Outside Diameter |
| N | Number of Turn in Coil |
| $^{\circ}\text{C}$ | Degree Celsius |
| m | Metre |
| m^2 | Square Metre |
| mm | Millimetre |
| kJ | Kilojoule |
| kg | Kilogram |
| hr | Hour |
| W | Watt |
| kW | Kilowatt |
| Gcal | Giga calorie |
| PCE | Purchase Cost of Equipment |
| PCC | Total Physical Plant Cost |

List of Figures

| | |
|--|----|
| Figure 1.1 Onion Diagram | 2 |
| Figure 3.1: Existing Process Flow Diagram | 13 |
| Figure 3.2: Combine Composite Curve | 42 |
| Figure 3.3: Grand Composite Curve | 43 |
| Figure 4.1 Defining Reference Streams | 45 |
| Figure 4.2: Defining Utility Stream | 46 |
| Figure 4.3: Unsatisfied Grid Diagram..... | 46 |
| Figure 4.4: Coil E 201 | 47 |
| Figure 4.5: Grid Diagram with E 201 | 47 |
| Figure 4.6: Coil E 202 | 48 |
| Figure 4.7: Grid Diagram with E 202 | 48 |
| Figure 4.8: Coil E 203 | 49 |
| Figure 4.9: Grid Diagram with E 203 | 49 |
| Figure 4.10: Coil E 204 A | 50 |
| Figure 4.11: Grid Diagram with E 204 A | 50 |
| Figure 4.12: Coil F 202 A | 51 |
| Figure 4.13: Grid Diagram with F 202 A..... | 51 |
| Figure 4.14: Coil E 205 | 52 |
| Figure 4.15: Grid Diagram with E 205 | 52 |
| Figure 4.16: Coil E 204 B | 53 |
| Figure 4.17: Grid Diagram with E 204 B..... | 53 |
| Figure 4.18: Coil E 206..... | 54 |
| Figure 4.19: Grid Diagram with E 206 | 54 |
| Figure 4.20: Existing Heat Exchanger Network Grid Diagram..... | 55 |
| Figure 4.21: High Pressure Steam Mass Flowrate | 55 |
| Figure 4.22: Process Flow Diagram for Existing Process | 56 |
| Figure 4.23: Case 1-Streams Data..... | 57 |
| Figure 4.24: Case 1-Grid Diagram..... | 57 |
| Figure 4.25: Case 1-Coil E 202 B | 57 |
| Figure 4.26: Case 1-Coil E 204 B | 58 |
| Figure 4.27: Case 1-Coil E 206..... | 58 |
| Figure 4.28: Case 2-Streams Data..... | 59 |
| Figure 4.29: Case 2-Grid Diagram..... | 59 |
| Figure 4.30: Case 2-E 204 B | 59 |
| Figure 4.31: Case 2-E 202 B | 60 |
| Figure 4.32: Case 2-E 206..... | 60 |
| Figure 4.33: Case 2-E 204 C | 61 |
| Figure 4.34: Case 3-Streams Data..... | 61 |
| Figure 4.35: Case 3-Grid Diagram..... | 62 |
| Figure 4.36: Case 3-E 202 B | 62 |
| Figure 4.37: Case 3-E 204 B | 62 |
| Figure 4.38: Case 3-E 206..... | 63 |

| | |
|--|-----|
| Figure 5.1: Modified Streams Data | 64 |
| Figure 5.2: Utility Stream | 64 |
| Figure 5.3: Modified Heat Exchanger Network..... | 65 |
| Figure 5.4: Coil E 201 | 65 |
| Figure 5.5: Coil E 202 A | 66 |
| Figure 5.6: Coil E 203 | 66 |
| Figure 5.7: Coil E 204 A | 67 |
| Figure 5.8: Coil F 202 A | 67 |
| Figure 5.9: Coil E 205 | 68 |
| Figure 5.10: Coil E 202 B | 68 |
| Figure 5.11: Coil E 204 B | 69 |
| Figure 5.12: Coil E 206..... | 69 |
| Figure 5.13: New High Pressure Steam Mass Flowrate | 70 |
| Figure 5.14 New Heat Exchanger Grid Network Design | 70 |
| Figure 5.15: New Process Flow Diagram | 71 |
| Figure 6.1: Balance Combine Composite Curve..... | 96 |
| Figure 7.1: Cost to Heat Transfer Area Graph..... | 100 |
| Figure 8.1: Components | 101 |
| Figure 8.2: Fluid Package | 101 |
| Figure 8.3: Simulation Model | 102 |
| Figure 8.4: Natural Gas | 103 |
| Figure 8.5: Recycle Gas | 103 |
| Figure 8.6: Natural & Recycle Gas | 104 |
| Figure 8.7: Desulphurized Natural Gas..... | 104 |
| Figure 8.8: Process Steam | 105 |
| Figure 8.9: Process Gas..... | 105 |
| Figure 8.10: Process Air..... | 106 |
| Figure 8.11: Boiler Feed Water..... | 106 |
| Figure 8.12: Steam from Steam Drum | 107 |
| Figure 8.13: Primary Reformer Flue Gas..... | 107 |
| Figure 8.14: Boiler Flue Gas | 108 |
| Figure 8.15: Combine Flue Gas | 108 |
| Figure 8.16: MIX-100 Design..... | 109 |
| Figure 8.17: MIX-100 Worksheet..... | 109 |
| Figure 8.18 MIX-101 Design..... | 110 |
| Figure 8.19: MIX-101 Worksheet..... | 110 |
| Figure 8.20: MIX-102 Design..... | 111 |
| Figure 8.21: MIX-102 Worksheet..... | 111 |
| Figure 8.22: Exchanger E 201 Design | 112 |
| Figure 8.23: Exchanger E 201 Worksheet | 112 |
| Figure 8.24: Exchanger E 202 A Design | 113 |
| Figure 8.25: Exchanger E 202 A Worksheet | 113 |
| Figure 8.26: Exchanger E 203 Design | 114 |
| Figure 8.27: Exchanger E 203 Worksheet | 114 |
| Figure 8.28: Exchanger E 204 A Design | 115 |
| Figure 8.29: Exchanger E 204 A Worksheet | 115 |

| | |
|---|-----|
| Figure 8.30: Exchanger F 202 A Design..... | 116 |
| Figure 8.31: Exchanger F 202 A Worksheet..... | 116 |
| Figure 8.32: Exchanger E 205 Design | 117 |
| Figure 8.33: Exchanger E 205 Worksheet | 117 |
| Figure 8.34: Exchanger E 202 B Design..... | 118 |
| Figure 8.35: Exchanger E 202 B Worksheet..... | 118 |
| Figure 8.36: Exchanger E 204 B Design..... | 119 |
| Figure 8.37: Exchanger E 204 B Worksheet..... | 119 |
| Figure 8.38: Exchanger E 206 Design | 120 |
| Figure 8.39: Exchanger E 206 Worksheet | 120 |
| Figure 8.40: Process Gas to Primary Reformer | 121 |
| Figure 8.41: Process Air to Secondary Reformer | 121 |
| Figure 8.42: Steam to Boiler | 122 |
| Figure 8.43: Natural & Recycle Gas to Desulphurizer | 122 |
| Figure 8.44: Boiler Feed Water Outlet..... | 123 |
| Figure 8.45: Stack Gas | 123 |
| Figure 8.46: High Pressure Generation | 124 |

List of Tables

| | |
|---|-----|
| Table 3-1: Natural Gas Composition..... | 15 |
| Table 3-2: Recycle Gas Composition..... | 16 |
| Table 3-3: Process Gas Composition..... | 16 |
| Table 3-4: Process Steam Composition..... | 16 |
| Table 3-5: Steam from Steam Drum Composition..... | 16 |
| Table 3-6: Boiler Feed Water Composition..... | 17 |
| Table 3-7: Primary Reformer Flue Gas Composition..... | 17 |
| Table 3-8: Boiler Flue Gas Composition..... | 17 |
| Table 3-9: Natural & Recycle Gas Composition..... | 20 |
| Table 3-10: Process Gas Composition..... | 24 |
| Table 3-11: Combine Flue Gas Composition..... | 28 |
| Table 3-12: Process Streams Data..... | 36 |
| Table 3-13: Process Streams Shifted Temperatures..... | 37 |
| Table 3-14: Problem Table Algorithm for Existing Plant..... | 39 |
| Table 3-15: Hot Process Streams Data..... | 40 |
| Table 3-16: Hot Composite Curve Streams Data..... | 41 |
| Table 3-17: Cold Process Streams Data..... | 41 |
| Table 3-18: Cold Composite Curve Stream Data..... | 42 |
| Table 3-19: Threshold Temperature..... | 44 |
| Table 5-1: Comparison of New and Existing Heat Exchanger Network..... | 73 |
| Table 6-1: Coils Design Summary..... | 90 |
| Table 6-2: Modified Streams Data..... | 91 |
| Table 6-3: Modified Streams Shifted Temperatures..... | 92 |
| Table 6-4: Problem Table Algorithm for Modified Data..... | 93 |
| Table 6-5: Modified Hot Streams Data..... | 94 |
| Table 6-6: Data for Hot Balance Composite Curve..... | 94 |
| Table 6-7: Modified Cold Streams Data..... | 95 |
| Table 6-8: Data for Cold Balance Composite Curve..... | 95 |
| Table 6-9: Area Targeting..... | 98 |
| Table 6-10: Area of Coils..... | 98 |
| Table 7-1: Fixed Capital (\$)..... | 99 |
| Table 7-2: Economic Analysis..... | 99 |
| Table 9-1: Guide Words for HAZOP..... | 125 |
| Table 9-2: HAZOP Study on Valve..... | 126 |
| Table 9-3: HAZOP Study of Coils..... | 127 |
| Table 9-4: HAZOP Study on Boiler..... | 128 |

Table of Contents

| | |
|--|----|
| Chapter 1 Introduction | 1 |
| 1.1 Background | 1 |
| 1.2 Problem Statement | 1 |
| 1.3 Purpose of Study | 2 |
| 1.4 What is Pinch Analysis? | 2 |
| Chapter 2 Literature Review | 4 |
| 2.1 Process Integration | 4 |
| 2.1.1 Mass Integration | 4 |
| 2.1.2 Heat Integration..... | 4 |
| 2.2 Pinch Analysis | 5 |
| 2.3 Steps of Pinch Analysis | 5 |
| 2.3.1 Identification of Hot, Cold & Utility Streams in the Process | 6 |
| 2.3.2 Thermal Data Extraction for the Process Streams | 6 |
| 2.3.3 Selection of Initial ΔT_{min} Value | 7 |
| 2.3.4 Construction of Composite & Grand Composite Curve | 8 |
| 2.3.5 Estimation of Minimum Energy Cost Targets | 9 |
| 2.3.6 Estimation of Heat Exchanger Network Capital Cost Targets... .. | 9 |
| 2.3.7 Estimation of Optimum ΔT_{min} Value..... | 10 |
| 2.3.8 Estimation of Targets of Heat Exchanger Network Design..... | 11 |
| 2.3.9 Design of Heat Exchanger Network | 12 |
| Chapter 3 Process Description | 13 |
| 3.1 Process Flow Diagram..... | 13 |
| 3.1.1 Natural Gas..... | 14 |
| 3.1.2 Process Air..... | 14 |
| 3.1.3 Steam from Steam Drum | 14 |
| 3.1.4 Boiler Feed Water | 14 |
| 3.1.5 Flue Gases..... | 14 |
| 3.2 Data Extraction | 15 |
| 3.3 Material Balance | 15 |
| 3.3.1 Mass Flowrates and Compositions of Known Streams | 15 |
| 3.3.2 Mass Flowrates and Compositions of Unknown Streams..... | 18 |
| 3.4 Energy Balance..... | 29 |

| | |
|--|-----------|
| 3.5 Data for Pinch Analysis..... | 36 |
| 3.6 Energy Targeting..... | 37 |
| 3.6.1 Shifted Temperatures | 37 |
| 3.6.2 Problem Table Algorithm | 37 |
| 3.6.3 Composite and Grand Composite Curve..... | 40 |
| 3.6.4 Threshold Temperature | 43 |
| Chapter 4 Aspen Energy Analyzer..... | 45 |
| 4.1 Data Entering | 45 |
| 4.1.1 Defining Process Streams | 45 |
| 4.2 Existing Heat Exchanger Network..... | 46 |
| 4.2.1 Unsatisfied Grid Diagram | 46 |
| 4.2.2 Coil E 201 | 47 |
| 4.2.3 Coil E 202 | 48 |
| 4.2.4 Coil E 203 | 49 |
| 4.2.5 Coil E 204 A..... | 50 |
| 4.2.6 Coil F 202 A..... | 51 |
| 4.2.7 Coil E 205 | 52 |
| 4.2.8 Coil E 204 B..... | 53 |
| 4.2.9 Coil E 206 | 54 |
| 4.2.9 Existing Heat Exchanger Network Grid Diagram | 55 |
| 4.2.10 High Pressure Steam Production in Coil E 205..... | 55 |
| 4.3 Analysis of the Existing Process..... | 55 |
| 4.3.1 Case 1..... | 57 |
| 4.3.2 Case 2..... | 59 |
| 4.3.3 Case 3..... | 61 |
| Chapter 5 New Heat Exchanger Network..... | 64 |
| 5.1 New Heat Exchanger Network Design | 64 |
| 5.1.1 Defining Process Streams | 64 |
| 5.1.2 Defining Utility Stream | 64 |
| 5.1.3 New Heat Exchanger Network | 65 |
| 5.1.4 New Heat Exchanger Network Grid Diagram | 70 |
| 5.2 Comparison of Networks | 71 |
| 5.2 New Process Flow Diagram | 71 |
| 5.3 Material and Energy Balance of New Process..... | 72 |

| | |
|---|------------|
| 5.3.1 Material Balance | 72 |
| 5.3.2 Energy Balance | 72 |
| Chapter 6 Coils Designing | 82 |
| 6.1 Design Parameters | 82 |
| 6.2 Designing of Coils..... | 83 |
| 6.2.1 Coil E 202 A..... | 83 |
| 6.2.2 Coil E 202 B..... | 84 |
| 6.2.3 Coil E 204 A..... | 86 |
| 6.2.4 Coil E 204 B..... | 87 |
| 6.2.5 Coil E 206..... | 88 |
| 6.3 Coil Design Summary..... | 90 |
| 6.4 Area Targeting..... | 91 |
| 6.4.1 Stream Data..... | 91 |
| 6.4.2 Problem Table Algorithm | 93 |
| 6.4.3 Balanced Combine Composite Curve..... | 94 |
| 6.4.4 Bath Algorithm..... | 96 |
| 6.3.4 Area Comparison | 98 |
| Chapter 7 Economic Analysis | 99 |
| 7.1 Cost of Coils | 99 |
| 7.2 Economic Analysis | 100 |
| Chapter 8 Aspen HYSYS Simulation | 101 |
| 8.1 HYSYS Simulation | 101 |
| 8.1.1 Components | 101 |
| 8.1.2 Fluid Package | 101 |
| 8.1.3 Model | 102 |
| 8.1.4 Defined Streams..... | 103 |
| 8.1.5 Mixers..... | 109 |
| 8.1.6 Heat Exchangers | 112 |
| 8.1.7 Product Streams..... | 121 |
| 8.2 Results | 124 |
| Chapter 9 HAZOP Analysis | 125 |
| 9.1 Why HAZOP?..... | 125 |
| 9.2 Analysis | 126 |
| 9.2.1 Valve..... | 126 |

| | |
|-----------------------------------|------------|
| 9.2.2 Coils | 126 |
| 9.2.3 Boiler | 128 |
| Chapter 10 Conclusion..... | 129 |
| References..... | 130 |

Abstract

Around 80% of ammonia produced is being used for the manufacturing of urea-based fertilizers, however its production requires extensive amount of energy.

Retrofitting of an existing ammonia plant for improving energy efficiency is done by using Pinch Analysis. This method relates the core process with the utility system to reduce the energy consumption and heat waste of the plant. The technique is applied on the convective section of the primary reformer by changing the arrangement of heating coils and by doing this significant waste heat was recovered from the flue gases. Otherwise, this heat would have lost in atmosphere. The analysis was performed using Aspen Energy Analyser. The problem came out be threshold problem i.e. the system requires only one utility (cold utility) to meet the desired temperatures of different streams. Using thermodynamics principles, pinch rules and limitation imposed by the current plant design, new modifications are suggested to improve the plant efficiency. As a result of these suggestions, around 7% more high pressure steam can be generated with only slight modifications.

Chapter 1

Introduction

1.1 Background

Fauji Fertilizer Company Limited (FFC) was established back in 1978 and is one of the largest chemical fertilizer producer in Pakistan. The major products of FFC are urea and ammonia and have a capacity to produce more than 6000 metric tons of urea per day.

Ammonia is one of the most important chemical in the field of agriculture, as 80% of the produced ammonia is being used for manufacturing of fertilizers like urea, ammonium nitrate and ammonium phosphate, etc. Ammonia is also used in industrial refrigeration systems as coolant, for water and wastewater treatment, for making urea nitrate and for several metallurgical process. These mentioned uses of ammonia show its importance but the production of ammonia gas requires large amount of energy. Hence we need to design energy efficient plant with minimum heat wastage and maximum recovery.

The technique through which FFC used to produce ammonia in 1978 is now obsolete as new methods are developed using modern technology. The aim of using modern technology is to develop efficient plants that give maximum output for the same amount of inputs.

1.2 Problem Statement

Currently in Plant II of FFC, the flue gases from primary reformer and auxiliary boiler are leaving the system at sufficiently high temperature into atmosphere. This shows the plant is not being operated to its full potential along with high adverse effects on the environment. The flue gases are the source for heat recovery and by using modern

engineering tools this recoverable energy can be used to heat other process stream or to produce steam.

1.3 Purpose of Study

No matter how carefully the process is designed, there is always some room to improve the process efficiency through different modifications. Pinch Analysis is one of the advance technique through which industry can modify their process for heat integration. It is a well-defined method to relate plant's core streams with the utility system, such that maximum energy is recovered.

1.4 What is Pinch Analysis?

It was first introduced by Bodo Linnhoff and Vredeveld. Pinch analysis is a methodology for minimising energy consumption of chemical processes by calculating thermodynamically feasible energy targets (or minimum energy consumption).




Figure 1.1 Onion Diagram

Designing of new process start with the reactors i.e. the core of the onion. Separators, the second layer of onion, are designed once feed, product, flowrates and recycle concentrations are known. After

complete material and energy balance is performed on the new system, heat exchanger network is designed. This is where pinch analysis comes in, it provides a systematic approach to relate core process (first and second layer of onion) with the utility system (fourth layer of onion), while saving energy. Pinch analysis defines targets including minimum energy requirement, exchanger area and minimum cost prior to heat exchanger network design. The heat exchanger network designed through pinch rules ensure that these targets are meet and energy is saved. Thus, the prime objective of the technique is to achieve financial saving by maximizing process to process heat recovery and reducing the external utility loads, i.e. by better process heat integration.

Now a days, number of software have been developed to perform pinch analysis on industries complex process with speed and efficiency. Aspen Energy Analyzer is one of the famous product of Aspen One that is used to perform pinch analysis. The problem in this thesis is done by using Aspen Energy Analyzer.

Chapter 2

Literature Review

2.1 Process Integration

Process integration means to optimize a process for reducing the amount of raw material, minimize waste and utility requirement. It can be done by recycling the useful waste materials and recover waste heat that is being generated by different processes.

Process integration has two divisions.

1. Mass Integration
2. Heat Integration

2.1.1 Mass Integration

Objective of mass integration are:

- To achieve maximum product yield.
- Minimizing waste material.
- Decreasing the requirement of fresh feed.

2.1.2 Heat Integration

Objective of heat integrations:

- Calculating minimum heating and cooling duties to operate plant.
- Designing heat exchanger network to meet the initially set targets.
- Converting waste heat into valuable energy.

Different techniques used to perform process integration are:

- Pinch Analysis
- Process Graph theory Process
- State space approach
- Genetic Algorithm

Out of these, pinch analysis is one of the most common technique and widely used technique to perform process (heat) integration.

2.2 Pinch Analysis

Pinch analysis is based on the principles of thermodynamics. The First Law of thermodynamics helps to determine the change in enthalpy (ΔH) of the streams passing through heat exchanger. The Second Law determines the direction of heat flow that is from hot stream to cold stream. Temperature crossovers of the hot and cold stream profile (temperature vs enthalpy) is restricted by second law. Temperature crossover means that hot stream cannot be cooled to the temperature lower than cold stream supply temperature and vice versa. Temperature approach of heat exchanger defines the limit to which a hot stream can be cooled to. This is the minimum allowable temperature difference (ΔT_{\min}) between hot and cold stream. The point at which minimum temperature difference (ΔT_{\min}) occur in known as pinch point in the profile. The pinch defines the minimum driving force allowed in the exchanger unit.

The goal of any process industry is to minimize the utility requirement and maximize process to process stream heat recovery. An optimize heat exchanger network is required for minimum energy requirement. To design the most suitable heat exchanger network, pinch analysis provides well defined steps. These can be used for a new project as well as for retrofitting and existing one.

2.3 Steps of Pinch Analysis

Steps used to perform pinch analysis are:

- Identification of hot, cold & utility streams in the process.
- Thermal data extraction for the process.
- Selection of initial minimum temperature difference (ΔT_{\min}) value.
- Construction of composite curve & grand composite curve.
- Estimation of minimum energy cost targets.

- Estimation of heat exchanger network capital cost targets.
- Estimation of optimum minimum temperature difference (ΔT_{\min}) value.
- Estimation of practical targets of heat exchanger network design.
- Design of heat exchanger network.

Details of these steps are discussed below:

2.3.1 Identification of Hot, Cold & Utility Streams in the Process

This step is the simplest yet the most crucial step in which process flow diagram of the plant is carefully analysed to identify hot, cold and utility streams. Hot streams are those which need to be cooled while cold stream are those which must be heated. Reactant stream normally require preheating before entering a reactor and hence are cold stream. If heat exchange between the process streams is not feasible or economical then utility streams are used as coolant to heating agents. Hot utilities include steam, hot oil or flue gases, etc. Cold utilities include cooling water, steam generation or air, etc.

2.3.2 Thermal Data Extraction for the Process Streams

Following stream data is required to perform pinch analysis:

- **Supply Temperature (T_s °C)**
- **Target Temperature (T_T °C)**
- **Heat Capacity Flow Rate (C_P kW/°C)**

Heat capacity flow rate is the product of mass flow rate (M kg/s) and specific heat capacity (c_p kJ/kg °C).

$$C_P = M \times c_p$$

- **Enthalpy Change (ΔH kW)**

According to first law of thermodynamics:

$$\Delta H = Q \pm W$$

For heat exchangers,

$$W = 0$$

So,

$$\Delta H = Q$$

Moreover,

$$Q = C_p (T_S - T_T)$$

- **Heat Transfer Coefficients (h W/m² °C)**

Heat transfer coefficients are required to calculate overall heat transfer coefficient (U W/m² °C) between the hot and cold streams in the heat exchanger. The overall heat transfer coefficient are used to calculate the area of heat exchangers.

$$\frac{1}{U} = \frac{1}{h_{Hot}} + \frac{1}{h_{Cold}}$$
$$A = \frac{Q}{U \times \Delta T_{LM}}$$
$$\Delta T_{LM} = \frac{(T_{Hin} - T_{Cout}) - (T_{Hout} - T_{Cin})}{\ln \frac{(T_{Hin} - T_{Cout})}{(T_{Hout} - T_{Cin})}}$$

Where ΔT_{LM} is log mean temperature difference.

2.3.3 Selection of Initial ΔT_{min} Value

For feasible heat transfer design, minimum driving force is required that is ΔT_{min} has to be maintained between the streams. Value of minimum temperature difference (ΔT_{min}) will depend on the physical properties of the exchanging streams and the type of heat exchanger that is being used.

Importance of selecting suitable minimum temperature difference (ΔT_{min}) value can be determine for the fact that it is the main controlling factor for both capital and energy costs. For a particular value of heat load (Q), if smaller value of minimum temperature difference (ΔT_{min}) is selected, then area requirement by the exchangers

rises. For the higher value, heat recovery will be reduced and utilities demand increase to meet the desired results.

2.3.4 Construction of Composite & Grand Composite Curve

2.3.4.1 Composite curves

Composite curves are temperature vs enthalpy (T-H) plot that is used to determine energy target prior to design. Composite curve is plot between the hot and cold stream. The minimum distance between these two composite curves is ΔT_{\min} . The point at which ΔT_{\min} occur is known as pinch point. Hot composite curve represents the heat source in the system while cold composite curve are the heat sink. Overlapping area of the two curves are maximum recoverable energy. The hot composite curve portion extended on left side of the plot beyond the cold composite curve represents minimum cold utility requirement while extended cold composite curve on right side of the plot represents minimum hot utility requirement. However, there is always a chance of error while using graphical method. To eliminate these error, Linnhoff developed a numerical approach known as the problem table algorithm to determine energy requirement.

2.3.4.2 Grand Composite curve

Grand composite curve is used to determine the type of utility required to satisfy supply temperatures of the process streams. It represents the variation of heat supply and demand within the process. GCC are used to maximize the use of cheaper utilities and minimize the requirement of expensive utility.

Method to plot the composite and grand composite will be discussed in later chapters while solving the project.

2.3.4.3 Threshold Problem

If the plant's streams require only one utility that is either hot or cold utility then such problem is known as threshold problem. The pinch point for these type of problem lies on the one side of the plot rather than in the middle. If the plant requires only cold utility, then pinch will lie

on the right end of the plot and if it requires hot utility, then pinch will lie in the left end of the plot. However, the problem will remain single utility dependent till a value of ΔT_{min} known as threshold temperature. After this, plant will require both hot and cold utilities.

2.3.5 Estimation of Minimum Energy Cost Targets

After determining the minimum utilities requirement and the type of utility to be used, energy cost can be determined by using following equation.

$$Total\ Energy\ Cost = \sum_{i=1}^i Q_i \times C_i$$

Where

Q_i = Duty of utility i (kW)

C_i = Unit cost of utility i (\$/kW yr)

i = Total number of utilities used

2.3.6 Estimation of Heat Exchanger Network Capital Cost Targets

Capital cost of the heat exchanger networks is dependent upon:

- Number of exchangers
- Overall network area
- Distribution of area between the exchangers.

While targeting the area before the network design, it is assumed that area is evenly distributed between the units.

2.3.6.1 Area Targeting

Minimum heat exchanger network area is calculated through following relation:

$$HEN\ Area_{min} = \sum_i \left[\frac{1}{\Delta T_{LM}} \sum_j \frac{q_j}{h_j} \right]$$

2.3.6.2 Number of Units Targeting

Minimum number of exchanger units are calculated by:

$$N_{min} = [N_h + N_c + N_u - 1]_{Above\ Pinch} + [N_h + N_c + N_u - 1]_{Below\ Pinch}$$

Where:

N_h = Number of hot streams

N_c = Number of cold streams

N_u = Number of utility streams

2.3.6.3 Heat Exchanger Network Capital Cost Targeting

After determining minimum area heat exchanger area and minimum number of units, capital cost of the heat exchanger can be determined by:

$$C(\$)_{HEN} = \left[N_{min} \left\{ a + b \left(\frac{A_{min}}{N_{min}} \right) \right\}^c \right]_{Above\ Pinch} \\ + \left[N_{min} \left\{ a + b \left(\frac{A_{min}}{N_{min}} \right) \right\}^c \right]_{Below\ Pinch}$$

where a, b and c are constants in exchanger cost law

$$Exchanger\ cost\ (\$) = a + b (Area)^c$$

2.3.7 Estimation of Optimum ΔT_{min} Value

ΔT_{min} can affect the system in following ways:

- Increasing minimum temperature difference (ΔT_{min}) value will give higher energy costs but lower capital cost.
- Decreasing minimum temperature difference (ΔT_{min}) value will give lower energy costs but higher capital cost.
- Optimum minimum temperature difference (ΔT_{min}) exists where both total annual cost of energy and capital costs are minimized.

2.3.8 Estimation of Practical Targets of Heat Exchanger

Network Design

In some cases optimum value of minimum temperature difference (ΔT_{\min}) might not be suitable for appropriate design. If the value small that means requires area will be large and network design will be much complicated. In these situations, higher value of minimum temperature difference (ΔT_{\min}) is preferred if the effect on marginal cost is low.

The pinch temperature divides the system in two parts such that each portion is in enthalpy balance with its utility. Following points must be kept in while designing a network

- No external heating below the pinch.
- No external cooling above the pinch.
- No heat transfer across the pinch.

If any of above mentioned points are not followed while designing a network, then more energy will be required than theoretically calculated using combine composite curves.

2.3.8.1 Plus/Minus Principle

There are several factors in the plant system that can be changed for changing the energy consumption of plant. This will result changes in the energy and material balance. The change in these factor may have a favourable impact on energy consumption, this is known as plus/minus principle.

Following are the guidelines that can be used to reduce utility loads.

- Increasing (+) in hot stream duty or decreasing (-) in cold stream duty above the pinch will reduce utility load.
- Increasing (+) in cold stream duty or decreasing (-) in hot stream duty below the pinch will reduce utility load.

2.3.9 Design of Heat Exchanger Network

Heat exchanger network is designed using Pinch Design Method (PDM). The pinch temperature divides the network grid diagram into two parts that are above and below the pinch. Heat exchanger networks for both part are designed separately. When no more process to process heat exchange is possible then utility streams are added in the grid. Some of the basic design rules to identify between which two stream an exchange is possible are given below:

- Divide the problem at the pinch.
- Design away from the pinch.
- Above the pinch,
 - match streams adjacent to the pinch if,

$$CP_{Hot} \leq CP_{Cold}$$

- $N_{Hot} \leq N_{Cold}$

Where:

N_{Hot} = Number of hot streams

N_{Cold} = Number of Cold Streams

- Use hot utility
- Below the pinch,
 - match streams adjacent to the pinch if,

$$CP_{Cold} \leq CP_{Hot}$$

- $N_{Cold} \leq N_{Hot}$

Where:

N_{Hot} = Number of hot streams

N_{Cold} = Number of Cold Streams

- Use cold utility
- If the stream matching criteria is not satisfied then split a stream.
- Maximize the exchanger heat loads.

In the following chapters, these steps are used to perform the pinch analysis on the ammonia plant.

Chapter 3

Process Description

In this chapter, the existing network of coils is discussed in detail followed by extraction of data required to perform pinch analysis.

3.1 Process Flow Diagram

In the convective section of primary reformer, series of coils are installed to preheat natural gas, process air, boiler feed water and to generate steam to recover heat from the flue gas.





Figure 3.1: Existing Process Flow Diagram



3.1.1 Natural Gas

Natural Gas at 38 °C is mixed with Recycled Gas coming at 117 °C and passed through two preheaters E 204 B and E 204 A, in respective order. Mixture of these gases then entered the desulphurizer at 418°C. Sulphur content of natural gas is reduced from 0.9 ppm to 5 ppb.

The Desulphurized Gas is mixed with process steam and heated in coil E 201 to 532 °C before entering into the primary reformer.

3.1.2 Process Air

Process Air after being compressed is preheated in coil E 202 from 177 °C to 492°C.

3.1.3 Steam from Steam Drum

Steam from steam drum is first heated in coil E 203 through flue gas from primary reformer and then in F 202 A through flue gas coming from boiler.

3.1.4 Boiler Feed Water

Boiler Feed Water is heated in coil E 206 from 110 °C to 136 °C through stack gases.

3.1.5 Flue Gases

Flue gas coming from primary reformer is passed through four series of coils, namely E 201, E 202, E 203 and E 204 A, its temperature drops from 990 °C to 604 °C and then mixed with flue gas from the boiler. These combine flue gases are used to produce high pressure steam in coil E 205. Before exhausting into the environment at 220 °C, they preheat natural gas and boiler feed water in coil E 204 B and E 206, respectively.

Now we will perform data extraction of the process.

3.2 Data Extraction

For data extraction, complete material and energy balance of the system is required. Following data is required for pinch analysis:

- Streams supply temperatures (T_s °C)
- Streams target temperatures (T_T °C)
- Streams mass flow rates (M kg/h)
- Streams specific heat capacities (c_p kJ/kg °C)
- Streams head load (Q kW)
- Heat transfer coefficients (h W/m² °C)

3.3 Material Balance

Material balance is performed to calculate the mass flow rates and well the composition of streams. Detail material balance is given below:

3.3.1 Mass Flowrates and Compositions of Known Streams

Following data is provided by the industry

Natural Gas

| Components | M (kg/hr) | Wt% |
|-------------------------------|--------------|-------------|
| N ₂ | 9435 | 24.67% |
| CO ₂ | 6588.214 | 17.23% |
| CH ₄ | 22104.286 | 57.80% |
| C ₂ H ₆ | 112.5 | 0.29% |
| Flow (Total) | 38240 | 100% |

Table 3-1: Natural Gas Composition

Recycled Gas

| Components | M (kg/hr) | Wt% |
|-------------------------------|----------------|-------------|
| H ₂ | 172.260 | 17.30% |
| N ₂ | 798.750 | 80.22% |
| CO | 0.000 | 0.00% |
| CO ₂ | 0.000 | 0.00% |
| Ar | 8.929 | 0.90% |
| CH ₄ | 15.000 | 1.51% |
| C ₂ H ₆ | 0.000 | 0.00% |
| H ₂ O | 0.804 | 0.08% |
| Flow (Total) | 995.742 | 100% |

Table 3-2: Recycle Gas Composition

Process Air

| Components | M (kg/hr) | Wt% |
|---------------------|-----------------|-------------|
| O ₂ | 10585.71 | 23.12% |
| N ₂ | 34436.25 | 75.20% |
| CO ₂ | 21.61 | 0.05% |
| Ar | 592.86 | 1.29% |
| H ₂ O | 153.48 | 0.34% |
| Flow (Total) | 45789.91 | 100% |

Table 3-3: Process Gas Composition

Process Steam

| Components | M (kg/hr) | Wt% |
|------------------|-----------|------|
| H ₂ O | 103950 | 100% |

Table 3-4: Process Steam Composition

Steam from Steam Drum

| Components | M (kg/hr) | Wt% |
|------------------|-----------|------|
| H ₂ O | 255379 | 100% |

Table 3-5: Steam from Steam Drum Composition

Boiler Feed Water

| Components | M (kg/hr) | Wt% |
|------------------|-----------|------|
| H ₂ O | 257959 | 100% |

Table 3-6: Boiler Feed Water Composition

Flue Gas from Primary Reformer

| Components | M (kg/hr) | Wt% |
|---------------------|------------------|-------------|
| O ₂ | 4305.25 | 1.70% |
| N ₂ | 180006.77 | 71.19% |
| CO ₂ | 37765.50 | 14.94% |
| Ar | 3007.13 | 1.19% |
| H ₂ O | 27776.39 | 10.98% |
| Flow (Total) | 252861.03 | 100% |

Table 3-7: Primary Reformer Flue Gas Composition

Flue Gas from Boiler

| Components | M (kg/hr) | Wt% |
|---------------------|-----------------|-------------|
| O ₂ | 1944.16 | 2.60% |
| N ₂ | 53362.16 | 71.37% |
| CO ₂ | 10702.51 | 14.31% |
| Ar | 892.63 | 1.19% |
| H ₂ O | 7870.61 | 10.53% |
| Flow (Total) | 74772.08 | 100% |

Table 3-8: Boiler Flue Gas Composition

However, information about combine Natural and Recycled Gas, Process Gas and Combine Flue Gas is need to be calculated used material balance techniques.

3.3.2 Mass Flowrates and Compositions of Unknown Streams

3.3.2.1 Mass Flowrate Calculations

Material Balance around Mixer of Natural and Recycled Gas

Let X be the flow rate of inlet stream Natural Gas = 38240 kg/hr

Let Y be the flow rate of inlet stream Recycle Gas = 995.742 kg/hr

Let Z be the flow rate of outlet stream (Natural and Recycled Gas) = ?

$$X + Y = Z$$

$$38240 + 995.742 = Z$$

So, Z = 39235.742 kg/hr

Component Balance

N₂ Balance

Let x be the mass fraction of N₂ in inlet stream Natural Gas = 0.2467

Let y be the mass fraction of N₂ in inlet stream Recycled Gas = 0.8022

Let z be the mass fraction of N₂ in outlet stream = ?

$$38240 \times 0.2467 + 995.742 \times 0.8022 = 39235.742 \times z$$

So, z = **0.2608**

H₂ Balance

Let x be the mass fraction of H₂ in inlet stream Natural Gas = 0

Let y be the mass fraction of H₂ in inlet stream Recycled Gas = 0.1730

Let z be the mass fraction of H₂ in outlet stream = ?

$$38240 \times 0 + 995.742 \times 0.1730 = 39235.742 \times z$$

So, z = **0.0044**

CO₂ Balance

Let x be the mass fraction of CO₂ in inlet stream Natural Gas = 0.1723

Let y be the mass fraction of CO₂ in inlet stream Recycled Gas = 0

Let z be the mass fraction of CO₂ in outlet stream = ?

$$38240 \times 0.1723 + 995.742 \times 0 = 39235.742 \times z$$

So, z = **0.1679**

Ar Balance

Let x be the mass fraction of Ar in inlet stream Natural Gas = 0

Let y be the mass fraction of Ar in inlet stream Recycled Gas = 0.0090

Let z be the mass fraction of Ar in outlet stream = ?

$$38240 \times 0 + 995.742 \times 0.0090 = 39235.742 \times z$$

So, z = **0.0002**

CH₄ Balance

Let x be the mass fraction of CH₄ in inlet stream Natural Gas = 0.5780

Let y be the mass fraction of CH₄ in inlet stream Recycled Gas = 0.0151

Let z be the mass fraction of CH₄ in outlet stream = ?

$$38240 \times 0.5780 + 995.742 \times 0.0151 = 39235.742 \times z$$

So, z = **0.5638**

C₂H₆ Balance

Let x be the mass fraction of C₂H₆ in inlet stream Natural Gas = 0.0029

Let y be the mass fraction of C₂H₆ in inlet stream Recycled Gas = 0

Let z be the mass fraction of C₂H₆ in outlet stream = ?

$$38240 \times 0.0029 + 995.742 \times 0 = 39235.742 \times z$$

So, z = **0.0029**

H₂O Balance

Let x be the mass fraction of H₂O in inlet stream Natural Gas = 0

Let y be the mass fraction of H₂O in inlet stream Recycled Gas = 0.0008

Let z be the mass fraction of H₂O in outlet stream = ?

$$38240 \times 0.7380 + 995.742 \times 0.0081 = 39235.742 \times z$$

So, z = **0**

| Components | Natural and Recycle Gas Mass Fraction | Wt% |
|-------------------------------|--|-------------|
| N ₂ | 0.1839 | 18.39% |
| H ₂ | 0.00430 | 0.43% |
| CO ₂ | 0.00754 | 0.75% |
| Ar | 0.0001 | 0.01% |
| CH ₄ | 0.6957 | 69.75% |
| C ₂ H ₆ | 0.0019 | 0.19% |
| H ₂ O | 0 | 0% |
| Total | 1 | 100% |
| M (kg/hr) | 39235.7 | |

Table 3-9: Natural & Recycle Gas Composition

Material Balance around Mixer of Process Steam and Desulphurized Gas

Let X be the flow rate of inlet stream Process Steam = 103950 kg/hr

Let Y be the flow rate of inlet stream Desulphurized Gas = 39235.4 kg/hr

Let Z be the flow rate of outlet stream Process Gas = ?

$$X + Y = Z$$

$$103950 + 39235.4 = Z$$

So, $Z = 105701.6 \text{ kg/hr}$

Component Balance

O₂ Balance

Let x be the mass fraction of O₂ in inlet stream Process Steam = 0

Let y be the mass fraction of O₂ in inlet stream Desulphurized Gas = 0.0044

Let z be the mass fraction of O₂ in outlet stream Process Gas = ?

$$10395 \times 0 + 39235.4 \times 0.0044 = 105701.6 \times z$$

So, $z = 0$

H₂ Balance

Let x be the mass fraction of H₂ in inlet stream Process Steam = 0

Let y be the mass fraction of H₂ in inlet stream Desulphurized Gas = 0.2608

Let z be the mass fraction of H₂ in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0.2608 = 105701.6 \times z$$

So, $z = 0.00007$

N₂ Balance

Let x be the mass fraction of N₂ in inlet stream Process Steam = 0

Let y be the mass fraction of N₂ in inlet stream Desulphurized Gas = 0

Let z be the mass fraction of N₂ in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0 = 105701.6 \times z$$

So, **z = 0.00432**

CO Balance

Let x be the mass fraction of CO in inlet stream Process Steam = 0

Let y be the mass fraction of CO in inlet stream Desulphurized Gas = 0.1679

Let z be the mass fraction of CO in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0.1679 = 105701.6 \times z$$

So, **z = 0**

CO₂ Balance

Let x be the mass fraction of CO₂ in inlet stream Process Steam = 0

Let y be the mass fraction of CO₂ in inlet stream Desulphurized Gas = 0.0002

Let z be the mass fraction of CO₂ in outlet stream (Process Gas) = ?

$$103950 \times 0 + 39235.4 \times 0.0002 = 105701.6 \times z$$

So, **z = 0.00278**

Ar Balance

Let x be the mass fraction of Ar in inlet stream Process Steam = 0

Let y be the mass fraction of Ar in inlet stream 2 Desulphurized Gas = 0.5638

Let z be the mass fraction of Ar in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0.5638 = 105701.6 \times z$$

So, z = 0

CH₄ Balance

Let x be the mass fraction of CH₄ in inlet stream Process Steam = 0

Let y be the mass fraction of CH₄ in inlet stream Desulphurized Gas = 0.0029

Let z be the mass fraction of CH₄ in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0.0029 = 105701.6 \times z$$

So, z = 0.00934

C₂H₆ Balance

Let x be the mass fraction of C₂H₆ in inlet stream Process Steam = 0

Let y be the mass fraction of C₂H₆ in inlet stream Desulphurized Gas = 0

Let z be the mass fraction of C₂H₆ in outlet stream Process Gas = ?

$$103950 \times 0 + 39235.4 \times 0 = 105701.6 \times z$$

So, z = 0.00005

H₂O Balance

Let x be the mass fraction of H₂O in inlet stream Process Steam = 1

Let y be the mass fraction of H₂O in inlet stream Desulphurized Gas = 0

Let z be the mass fraction of H₂O in outlet stream Process Gas = ?

$$103950 \times 1 + 39235.4 \times 0 = 105701.6 \times z$$

So, **z = 0.9834**

| Components | Process Gas Mass Fraction | Wt% |
|-------------------------------|----------------------------------|-------------|
| O ₂ | 0 | 0% |
| H ₂ | 0.00007 | 0.007% |
| N ₂ | 0.00432 | 0.432% |
| CO | 0 | 0% |
| CO ₂ | 0.00278 | 0.278% |
| Ar | 0 | 0% |
| CH ₄ | 0.00934 | 0.934% |
| C ₂ H ₆ | 0.00005 | 0.005% |
| H ₂ O | 0.9834 | 98.34% |
| Total | 1 | 100% |
| M (kg/hr) | 105701.6 | |

Table 3-10: Process Gas Composition

Material balance around Mixer of Flue Gas from Primary Reformer and Boiler

Let X be the flow rate of inlet stream of Primary Reformer Flue Gas = 252861.03 kg/hr

Let Y be the flow rate of inlet stream of Boiler Flue Gas = 74772.08 kg/hr

Let Z be the flow rate of outlet stream Combine Flue Gas = ?

$$X + Y = Z$$

$$252861.03 + 74772.08 = Z$$

So, **Z = 327633.11 kg/hr**

Component balance

O₂ Balance

Let x be the mass fraction of O₂ in inlet stream of Primary Reformer Flue Gas = 0.0170

Let y be the mass fraction of O₂ in inlet stream of Boiler Flue Gas = 0.0260

Let z be the mass fraction of O₂ in outlet stream of Combine Flue Gas = ?

$$252861.03 \times 0.0170 + 74772.08 \times 0.0260 = 327633.11 \times z$$

So, **z = 0.0191**

H₂ Balance

Let x be the mass fraction of H₂ in inlet stream of Primary Reformer Flue Gas = 0

Let y be the mass fraction of H₂ in inlet stream of Boiler Flue Gas = 0

Let z be the mass fraction of H₂ in outlet stream of Combine Flue Gas = ?

$$252861.03 \times 0 + 74772.08 \times 0 = 327633.11 \times z$$

So, **z = 0**

N₂ Balance

Let x be the mass fraction of N₂ in inlet stream of Primary Reformer Flue Gas = 0.7119

Let y be the mass fraction of N₂ in inlet stream of Boiler Flue Gas = 0.7137

Let z be the mass fraction of N₂ in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0.7119 + 74772.08 \times 0.7137 = 327633.11 \times z$$

So, z = **0.7123**

CO Balance

Let x be the mass fraction of CO in inlet stream of Primary Reformer Flue Gas = 0

Let y be the mass fraction of CO in inlet stream of Boiler Flue Gas = 0

Let z be the mass fraction of CO in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0 + 74772.08 \times 0 = 327633.11 \times z$$

So, z = **0**

CO₂ Balance

Let x be the mass fraction of CO₂ in inlet stream of Primary Reformer Flue Gas = 0.1494

Let y be the mass fraction of CO₂ in inlet stream of Boiler Flue Gas = 0.1431

Let z be the mass fraction of CO₂ in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0.1494 + 74772.08 \times 0.1431 = 327633.11 \times z$$

So, z = **0.1479**

Ar Balance

Let x be the mass fraction of Ar in inlet stream of Primary Reformer Flue Gas = 0.0119

Let y be the mass fraction of Ar in inlet stream of Boiler Flue Gas = 0.0119

Let z be the mass fraction of Ar in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0.0119 + 74772.08 \times 0.0119 = 327633.11 \times z$$

So, $z = 0.0191$

CH₄ Balance

Let x be the mass fraction of CH₄ in inlet stream Primary Reformer Flue Gas = 0.2467

Let y be the mass fraction of CH₄ in inlet stream of Boiler Flue Gas = 0

Let z be the mass fraction of CH₄ in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0.2467 + 74772.08 \times 0 = 327633.11 \times z$$

So, $z = 0$

C₂H₆ Balance

Let x be the mass fraction of C₂H₆ in inlet stream Primary Reformer Flue Gas = 0

Let y be the mass fraction of C₂H₆ in inlet stream of Boiler Flue Gas = 0

Let z be the mass fraction of C₂H₆ in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0 + 74772.08 \times 0 = 327633.11 \times z$$

So, $z = 0$

H₂O Balance

Let x be the mass fraction of H₂O in inlet stream Primary Reformer Flue Gas = 0.1098

Let y be the mass fraction of H₂O in inlet stream of Boiler Flue Gas = 0.1053

Let z be the mass fraction of H₂O in outlet stream Combine Flue Gas = ?

$$252861.03 \times 0.1098 + 74772.08 \times 0.1053 = 327633.11 \times z$$

So, z = **0.1088**

| Components | Combine Flue Gas Mass Fraction | Wt% |
|-------------------------------|---------------------------------------|-------------|
| O ₂ | 0.0190 | 1.9% |
| H ₂ | 0 | 0% |
| N ₂ | 0.7123 | 71.23% |
| CO | 0 | 0% |
| CO ₂ | 0.1479 | 14.79% |
| Ar | 0.019 | 1.9% |
| CH ₄ | 0 | 0% |
| C ₂ H ₆ | 0 | 0% |
| H ₂ O | 0.1088 | 10.88% |
| Total | 1 | 100% |
| Mass Flow (kg/hr) | 327633.11 | |

Table 3-11: Combine Flue Gas Composition

3.4 Energy Balance

Reference Temperature = 25 °C

Balance on Natural and Recycle Gas Mixer

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | H _{In} (kJ/hr) |
|--------------------------|--------------|------------------------------|------------------------|----------------------------|
| Natural Gas | 38240 | 1.92 | 38 | 954470.4 |
| Recycle Gas | 996 | 3.87 | 117 | 354615.84 |
| Natural & Recycle Gas | 39210 | 1.99 | 41.9 | 1318671.51 |

$$\Delta H_{In} = \Delta H_{Natural\ Gas} + \Delta H_{Recycle\ Gas}$$

$$\Delta H_{In} = 954470.4 + 354615.84$$

$$\Delta H_{In} = 1309086.24\text{ kJ/hr}$$

$$\Delta H_{Out} = 1318671.51\text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Desulphurized Gas and Process Steam Mixer

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | H _{In} (kJ/hr) |
|--------------------------------------|--------------|------------------------------|------------------------|----------------------------|
| Process Steam | 103950 | 2.52 | 380 | 92993670 |
| Desulphurized Gas | 39210 | 2.42 | 413 | 36816621.6 |
| Process Steam & Desulphurized Gas | 143071 | 2.49 | 390 | 130030078.4 |

$$\Delta H_{In} = \Delta H_{Process\ Steam} + \Delta H_{Desulphurized\ Gas}$$

$$\Delta H_{In} = 92993670 + 36816621.6$$

$$\Delta H_{In} = 129810291.6\text{ kJ/hr}$$

$$\Delta H_{Out} = 130030078\text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Primary Reformer Flue Gas and Boiler Flue Gas Mixer

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | H _{In} (kJ/hr) |
|---------------------------|--------------|------------------------------|------------------------|----------------------------|
| Primary Reformer Flue Gas | 252861 | 1.3 | 604 | 190328499.5 |
| Boiler Flue Gas | 74772 | 1.26 | 497 | 44468452.52 |
| Combined Flue Gas | 327633 | 1.19 | 580 | 216385214.9 |

$$\Delta H_{In} = \Delta H_{\text{Primary Reformer Flue Gas}} + \Delta H_{\text{Boiler Flue Gas}}$$

$$\Delta H_{In} = 170328499.5 + 44468452.52$$

$$\Delta H_{In} = 214796952 \text{ kJ/hr}$$

$$\Delta H_{Out} = 234796952 \text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Coil E 201

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|---------------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Process Gas | 143071 | 2.49 | 390 | 532 | 130030078.4 | 180617122.5 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 990 | 840 | 324534492.7 | 274088716.6 |

$$\text{Duty E 201} = Q_{E 201} = 12.06 \text{ Gcal/hr} = 50410800 \text{ kJ/hr}$$

For Process Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 180617122.5 - 130030078.4 = 50587044.18 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 201} \cong Q$$

For Primary reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 1324534492.7 - 274088716.6 = 50445776.07 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 201} \cong Q$$

Balance on Coil E 202

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|---------------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Process Air | 45761 | 1.07 | 177 | 492 | 130030078.4 | 22866314.09 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 840 | 794 | 274088716.6 | 256674177.3 |

$$\text{Duty E 202} = Q_{E\ 202} = 3.68 \text{ Gcal/hr} = 15382400 \text{ kJ/hr}$$

For Process Air,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 22866314.09 - 130030078.4 = 15423745.05 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 202} \cong Q$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 274088716.6 - 256674177.3 = 17414539.34 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 202} \cong Q$$

Balance on Coil E 203

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|---------------------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Steam from Steam Drum | 143071 | 2.49 | 319 | 348 | 316092803.5 | 345622277.2 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 794 | 655 | 256674177.3 | 207093186 |

$$\text{Duty E 203} = Q_{E\ 203} = 10.9 \text{ Gcal/hr} = 45562000 \text{ kJ/hr}$$

For Steam from Steam Drum,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 345622277.2 - 316092803.5 = 29529473.77 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 203} \cong Q$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 256674177.3 - 207093186 = 49580991.34 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 203} \cong Q$$

Balance on Coil E 204 A

| Stream | M (kg/hr) | c _p (kJ/kg K) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|---------------------------------|--------------|-----------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Natural and Recycle Gas | 39210 | 2.2 | 247 | 418 | 17322193.8 | 33900966 |
| Primary Reformer Flue Gas | 252861 | 1.3 | 655 | 604 | 207093186 | 190328499.5 |

$$\text{Duty E 204 A} = Q_{E\ 204\ A} = 3.87 \text{ Gcal/hr} = 16176600 \text{ kJ/hr}$$

For Natural and Recycle Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 33900966 - 17322193.8 = 16578772.2 \text{ kJ/hr}$$

$$\text{So, } Q_{E204 A} \cong Q$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 207093186 - 190328499.5 = 16764686.48 \text{ kJ/hr}$$

$$\text{So, } Q_{E 204 A} \cong Q$$

Balance on Coil F 202 A

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|--------------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Steam from Steam Drum | 255379 | 4.19 | 348 | 375 | 345622277.2 | 374513303.5 |
| Boiler Flue Gas | 74772 | 1.26 | 805 | 497 | 73486002.05 | 44468452.52 |

$$\text{Duty F 202 A} = Q_{F 202 A} = 6.93 \text{ Gcal/hr} = 28967400 \text{ kJ/hr}$$

For Steam from Steam Drum,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 374513303.5 - 345622277.2 = 28891026.27 \text{ kJ/hr}$$

$$\text{So, } Q_{F 202 A} \cong Q$$

For Boiler Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 73486002.05 - 44468452.52 = 29017549.53 \text{ kJ/hr}$$

$$\text{So, } Q_{F 202 A} \cong Q$$

Balance on Heat Exchanger E 205

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|----------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Combined Flue Gas | 327633 | 1.19 | 580 | 336 | 216385214.9 | 118196881.1 |

$$\text{Duty E 205} = Q_{E\ 205} = 22.81 \text{ Gcal/hr} = 95345800 \text{ kJ/hr}$$

For Combined Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 216385214.9 - 118196881.1 = 98188333.7 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 205} \cong Q$$

Balance on Coil E 204 B

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|----------------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Natural and Recycle Gas | 39210 | 2.49 | 41.9 | 247 | 1318671.51 | 17322193.8 |
| Combined Flue Gas | 327633 | 1.16 | 336 | 294 | 118196881.1 | 101353268.6 |

$$\text{Duty E 204 B} = Q_{E\ 204\ B} = 3.82 \text{ Gcal/hr} = 15967600 \text{ kJ/hr}$$

For Natural and Recycle gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 17322193.8 - 1318671.51 = 16003522.29 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 204\ B} \cong Q$$

For Combined Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 118196881.1 - 101353268.6 = 16843612.53 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 204\ B} \cong Q$$

Balance on Coil E 206

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|----------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Boiler Feed Water | 257959 | 4.2 | 110 | 136 | 92091363 | 119974151.3 |
| Combined Flue Gas | 327633 | 1.16 | 294 | 220 | 101353268.6 | 73471700.25 |

Duty E 206 = $Q_{E\ 206}$ = 6.64 Gcal/hr = 27755200 kJ/hr

For Boiler Feed Water,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 119974151.3 - 92091363 = 27882788.31 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 206} \cong Q$$

For Combined Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 101353268.6 - 7347100.25 = 27881568.3 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 206} \cong Q$$

3.5 Data for Pinch Analysis

Following data is extracted after performing energy and material balance on the primary reformer convective section.

| Process Streams | M (kg/hr) | c_p (kJ/kg °C) | C_p (kW/°C) | T_s (°C) | T_T (°C) | ΔH (kJ/hr) | h (W/m ² °C) |
|---------------------------|-----------|------------------|---------------|------------|------------|--------------------|---------------------------|
| Natural & Recycle Gas | 39210 | 2.18 | 23.72 | 41 | 418 | 8943.5 | 116.4 |
| Process Air | 45761 | 1.07 | 13.59 | 177 | 492 | 4279.8 | 115.0 |
| Process Gas | 143071 | 2.67 | 106.26 | 400 | 532 | 14026 | 170.8 |
| Steam from Steam Drum | 255379 | 5.22 | 370.29 | 319 | 375 | 20736 | 70.0 |
| BFW | 257959 | 4.15 | 297.01 | 110 | 136 | 7722 | 5721 |
| Primary Reformer Flue Gas | 252861 | 1.31 | 91.93 | 990 | 604 | 35483 | 200.0 |
| Boiler Flue Gas | 74772 | 1.26 | 26.17 | 805 | 497 | 8059.6 | 200.0 |
| Combine Flue Gas | 327633 | 1.18 | 107.48 | 580 | 220 | 38693 | 338.3 |

Table 3-12: Process Streams Data

In this problem five streams have to be heated to desired temperature while there are three streams that require cooling. Note that intermediate temperatures are not required while performing a pinch analysis. Heat transfer coefficient is required to perform area targeting and calculating the area of new designed coils.

The minimum temperature difference (ΔT_{\min}) in this problem is 27 °C. At any point in the heat exchanger, temperature difference between the hot and cold streams cannot be less than 27 °C.

3.6 Energy Targeting

Using pinch analysis, it is possible estimate minimum energy requirement before designing the heat exchanger network. For this purpose problem table algorithm is used. Following calculations will be used to target energy for the process.

3.6.1 Shifted Temperatures

Shifted temperatures are calculated by following equations.

For Cold stream, $Shift\ Temperature = Temperature + \frac{1}{2} \Delta T_{min}$

For Hot stream, $Shift\ Temperature = Temperature - \frac{1}{2} \Delta T_{min}$

| Process Streams | T _S (°C) | T _T (°C) | Stream Type | Shift T _S (°C) | Shift T _T (°C) |
|---------------------------|------------------------|------------------------|----------------|------------------------------|------------------------------|
| Natural & Recycle Gas | 41 | 418 | Cold | 54.5 | 431.5 |
| Process Air | 177 | 492 | Cold | 190.5 | 505.5 |
| Process Gas | 400 | 532 | Cold | 413.5 | 545.5 |
| Steam | 319 | 375 | Cold | 332.5 | 388.5 |
| BFW | 110 | 136 | Cold | 123.5 | 149.5 |
| Primary Reformer Flue Gas | 990 | 604 | Hot | 976.5 | 590.5 |
| Boiler Flue Gas | 805 | 497 | Hot | 791.5 | 483.5 |
| Combine Flue Gas | 580 | 220 | Hot | 566.5 | 206.5 |

Table 3-13: Process Streams Shifted Temperatures

3.6.2 Problem Table Algorithm

These shifted temperature are then arrange in descending order and any repeated values are omitted. Temperature difference, net heat capacity and heat loads are calculated for each interval using following equations.

$$\Delta T = T_{(i+1)} - T_i$$

$$dH = C_{P\ Net} \times \Delta T$$

$$C_{P\ Net} = \sum C_{P\ Hot} - \sum C_{P\ Cold}$$

If enthalpy change (dH) of the interval is positive, then it has heat surplus and if the value of enthalpy change (dH) is negative then it demands heat. According to second law of thermodynamics, each upper interval can transfer heat to the lower interval as heat is transferred from higher temperature to lower temperature. First, infeasible cascade is determined by supply zero heat in the start and if the interval has surplus heat then it is added to the net heat load and if it demands heat then it is subtracted from the net heat load. If there is any negative value in the infeasible cascade then this heat is supplied in the start to form a feasible cascade. Surplus heat supplied in start is the minimum hot utility demand and heat left at end is the minimum cold utility. In this way, problem table algorithm is used to target the energy before designing the network.

In this problem, infeasible and feasible cascade are same because hot utility demand of the system is zero and minimum cold utility demand is calculated at the end.

| Shift Temperature (°C) | Interval | $T_{(i+1)}-T_i$ (°C) | Cp_{Net} (kW/°C) | dH (kW) | | Infeasible/ Feasible Cascade |
|------------------------|----------|----------------------|--------------------|---------|-------|------------------------------|
| 976.5 | | | | | Pinch | 0 |
| | 1 | 185 | 91.92 | 17006 | S | |
| 791.5 | | | | | | 17006 |
| | 2 | 201 | 118.09 | 23736 | S | |
| 590.5 | | | | | | 40743 |
| | 3 | 24 | 26.16 | 628 | S | |
| 566.5 | | | | | | 41371 |
| | 4 | 21 | 128.25 | 2693 | S | |
| 545.5 | | | | | | 44064 |
| | 5 | 40 | 22.1 | 880 | S | |
| 505.5 | | | | | | 44944 |
| | 6 | 22 | 8.42 | 185 | S | |
| 483.5 | | | | | | 45130 |
| | 7 | 52 | -17.75 | -923 | D | |
| 431.5 | | | | | | 44207 |
| | 8 | 18 | -41.47 | -746 | D | |
| 413.5 | | | | | | 43460 |
| | 9 | 25 | 64.78 | 1619 | S | |
| 388.5 | | | | | | 45080 |
| | 10 | 56 | -305.5 | -17108 | D | |
| 332.5 | | | | | | 27971 |
| | 11 | 142 | 64.78 | 9199 | S | |
| 190.5 | | | | | | 37170 |
| | 12 | 3 | 78.36 | 235 | S | |
| 187.5 | | | | | | 37405 |
| | 13 | 38 | -23.72 | -901 | D | |
| 149.5 | | | | | | 36504 |
| | 14 | 26 | -320.73 | -8339 | D | |
| 123.5 | | | | | | 28165 |
| | 15 | 69 | -23.72 | -1636 | D | |
| 54.5 | | | | | | 26528 |

Table 3-14: Problem Table Algorithm for Existing Plant

Pinch temperature is 976.5 °C. Hot and cold pinch are 990 °C and 963 °C, respectively. They are calculated by

$$\text{Hot Pinch} = \text{Pinch Temperature} + \frac{1}{2} \Delta T_{\min}$$

$$\text{Hot Pinch} = 976.5 + \frac{1}{2} \times 27 = 990 \text{ °C}$$

$$\text{Cold Pinch} = \text{Pinch Temperature} - \frac{1}{2} \Delta T_{\min}$$

$$\text{Cold Pinch} = 976.5 - \frac{1}{2} \times 27 = 963 \text{ °C}$$

The minimum hot utility requirement is 0 kW while minimum cold utility requirement is 25268 kW. So, it is a threshold problem.

3.6.3 Composite and Grand Composite Curve

Composite Curve is a plot between the actual temperature and heat flow. Calculations are:

For hot composite curve, arrange the supply and target temperatures of hot streams in descending order and calculate the value of heat capacity (C_p) in each interval. The product of the temperature difference and heat capacity will give the value of heat flow. Plot temperatures against heat flow.

| Process Stream | T_s (°C) | T_T (°C) | C_p (kW/°C) |
|---------------------------|------------|------------|---------------|
| Primary Reformer Flue Gas | 990 | 604 | 91.9 |
| Boiler Flue Gas | 805 | 497 | 26.2 |
| Combine Flue Gas | 580 | 220 | 107.5 |

Table 3-15: Hot Process Streams Data

| Actual Temperature (°C) | Interval | $T_{(i+1)}-T_i$ (°C) | $\Sigma C_{P \text{ Hot}}$ (kW/°C) | Heat Flow (kW) | Total Head Load (kW) |
|--------------------------------|-----------------|--|--|-----------------------|-----------------------------|
| 220 | | | | | |
| 497 | 1 | 277 | 107.5 | 29777.5 | 29777.5 |
| 580 | 2 | 83 | 133.7 | 11097.1 | 40874.6 |
| 604 | 3 | 24 | 26.2 | 628.8 | 41503.4 |
| 805 | 4 | 201 | 118.1 | 23738.1 | 65241.5 |
| 990 | 5 | 185 | 91.9 | 17000.2 | 23524.3 |

Table 3-16: Hot Composite Curve Streams Data

Similarly, for cold streams

| Process Stream | T_S (°C) | T_T (°C) | C_P (kW/°C) |
|-----------------------|------------------------------|------------------------------|---------------------------------|
| Natural & Recycle Gas | 41.9 | 418 | 23.72 |
| Process Air | 177 | 492 | 13.6 |
| Process Gas | 390 | 532 | 106.3 |
| Steam from Steam Drum | 319 | 375 | 370.3 |
| Boiler Feed Water | 110 | 136 | 107.5 |

Table 3-17: Cold Process Streams Data

| Actual Temperature (°C) | Interval | $T_{(i+1)}-T_i$ (°C) | $\Sigma C_{P \text{ Cold}}$ (kW/°C) | Heat Flow (kW) | Total Head Load (kW) |
|-------------------------|----------|----------------------|-------------------------------------|----------------|----------------------|
| 41.9 | | | | | |
| 110 | 1 | 68.1 | 23.72 | 1615.3 | 1615.3 |
| 136 | 2 | 23 | 131.22 | 3018 | 4633.3 |
| 177 | 3 | 41 | 23.72 | 972.5 | 5605.8 |
| 319 | 4 | 142 | 37.32 | 5299 | 10904.8 |
| 375 | 5 | 56 | 407.6 | 22825.6 | 33730.4 |
| 390 | 6 | 15 | 37.32 | 559.8 | 34290.2 |
| 418 | 7 | 28 | 143.6 | 4020.8 | 38311 |
| 492 | 8 | 74 | 119.9 | 8872.6 | 47183.6 |
| 532 | 9 | 40 | 106.3 | 4252 | 51435.6 |

Table 3-18: Cold Composite Curve Stream Data

Now plot the actual temperatures and heat flow for hot and cold streams on the graph to obtain combine composite curve.




Figure 3.2: Combine Composite Curve

Grand composite curve is a plot between shifted temperature and the net heat flow or the feasible cascade.




Figure 3.3: Grand Composite Curve

3.6.4 Threshold Temperature

Threshold temperature will only require one utility till a temperature limit known as threshold temperature that is 310 °C. After this, system requires both utilities. The following table shows the value of hot and cold utilities for different values of minimum temperature difference (ΔT_{\min}).

| ΔT_{\min} (°C) | Hot Pinch (°C) | Cold Pinch (°C) | Hot Utility (kW) | Cold Utility (kW) |
|---------------------------|-------------------|--------------------|---------------------|----------------------|
| 310 | 629 | 319 | 1670.6942 | 28198.674 |
| 295.75 | 990 | 694.25 | 0 | 26527.98 |
| 281.5 | 990 | 708.5 | 0 | 26527.98 |
| 267.25 | 990 | 722.75 | 0 | 26527.98 |
| 253 | 990 | 737 | 0 | 26527.98 |
| 238.75 | 990 | 751.25 | 0 | 26527.98 |
| 224.5 | 990 | 765.5 | 0 | 26527.98 |
| 210.25 | 990 | 779.75 | 0 | 26527.98 |
| 196 | 990 | 794 | 0 | 26527.98 |
| 181.75 | 990 | 808.25 | 0 | 26527.98 |
| 167.5 | 990 | 822.5 | 0 | 26527.98 |
| 153.25 | 990 | 836.75 | 0 | 26527.98 |
| 139 | 990 | 851 | 0 | 26527.98 |
| 124.75 | 990 | 865.25 | 0 | 26527.98 |
| 110.5 | 990 | 879.5 | 0 | 26527.98 |
| 96.25 | 990 | 893.75 | 0 | 26527.98 |
| 82 | 990 | 908 | 0 | 26527.98 |
| 67.75 | 990 | 922.25 | 0 | 26527.98 |
| 53.5 | 990 | 936.5 | 0 | 26527.98 |
| 39.25 | 990 | 950.75 | 0 | 26527.98 |
| 25 | 990 | 965 | 0 | 26527.98 |

Table 3-19: Threshold Temperature

Chapter 4

Aspen Energy Analyzer

Heat Exchanger Network is designed using Aspen Energy Analyzer. Details to design existing heat exchanger network on Aspen Energy Analyzer is discussed in following section.

4.1 Data Entering

4.1.1 Defining Process Streams

Following process streams data will be entered into aspen energy analyser.


- Name of the stream
- Inlet Temperature
- Outlet Temperature
- Mass Flowrate
- Specific Heat Capacity
- Heat Transfer Coefficient

| Name | Inlet T [C] | Outlet T [C] | MCp [kJ/C-h] | Enthalpy [kJ/h] | Segm. | HTC [kJ/h-m2-C] | Flowrate [kg/h] | Effective Cp [kJ/kg-C] | DT Cont. [C] |
|-------------|-------------|--------------|--------------|-----------------|-------|-----------------|-----------------|------------------------|--------------|
| P FG | 990.0 | 604.0 | ... | 1.277e+008 | | ... | 2.529e+005 | ... | Global |
| B FG | 805.0 | 497.0 | 9.421e+004 | 2.902e+007 | | 720.0 | 7.477e+004 | 1.260 | Global |
| C FG | 580.0 | 220.0 | ... | 1.390e+008 | | ... | 3.276e+005 | ... | Global |
| Process Gas | 390.0 | 532.0 | 3.562e+005 | 5.059e+007 | | 615.0 | 1.431e+005 | 2.490 | Global |
| Process Air | 177.0 | 492.0 | 4.896e+004 | 1.542e+007 | | 414.3 | 4.576e+004 | 1.070 | Global |
| BFW 1 | 319.0 | 375.0 | ... | 7.465e+007 | | ... | 2.554e+005 | ... | Global |
| NG + RG | 41.9 | 418.0 | ... | 3.223e+007 | | ... | 3.921e+004 | ... | Global |
| BFW | 110.0 | 136.0 | 1.071e+006 | 2.783e+007 | | 20598.0 | 2.580e+005 | 4.150 | Global |
| **New** | | | | | | | | | |

Figure 4.1 Defining Reference Streams

4.1.2 Defining Utility Stream

After defining process streams, utility is defined for the system. Only cold utility is required here. The cold utility is High Pressure Steam Generation of 110 Bars at 320 °C.



| Name | Inlet T [C] | Outlet T [C] | Cost Index [Cost/kJ] | Segm. | HTC [kJ/h-m ² -C] | Target Load [kJ/h] | Effective Cp [kJ/kg-C] | Target Flowrate [kg/h] | DT Cont. [C] |
|--|-------------|--------------|----------------------|-------|------------------------------|--------------------|------------------------|------------------------|--------------|
| HP Steam Generation - 110 Bar <empty> | 319.0 | 320.0 | -2.490e-006 | | 2.160e+004 | 9.501e+007 | 1500 | 6.334e+004 | Global |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

Process Streams Utility Streams Economics Options Notes

Set Up Operations Convert to HI Project Hot Sufficient Cold Sufficient

Figure 4.2: Defining Utility Stream

4.2 Existing Heat Exchanger Network

Existing heat exchanger network design is as followed:

4.2.1 Unsatisfied Grid Diagram

In this problem, there are three hot streams while five cold streams. The unsatisfied streams are represented by the dotted line. When the stream is satisfied, it is represented by solid line.




Figure 4.3: Unsatisfied Grid Diagram

4.2.2 Coil E 201

Now heat exchanger between Primary Reformer Flue Gas and Process Gas placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.4: Coil E 201




Figure 4.5: Gird Diagram with E 201

4.2.3 Coil E 202

Now heat exchanger between Primary Reformer Flue Gas and Process Air placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.6: Coil E 202




Figure 4.7: Gird Diagram with E 202

4.2.4 Coil E 203

Now heat exchanger between Primary Reformer Flue Gas and Steam from Steam Drum placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.8: Coil E 203




Figure 4.9: Gird Diagram with E 203

4.2.5 Coil E 204 A

Now heat exchanger between Primary Reformer Flue Gas and Natural & Recycle Gas is placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.10: Coil E 204 A




Figure 4.11: Gird Diagram with E 204 A

4.2.6 Coil F 202 A

Now heat exchanger between Boiler Flue gas and Steam from Steam Drum placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.12: Coil F 202 A




Figure 4.13: Gird Diagram with F 202 A

4.2.7 Coil E 205

Now high pressure steam generator is added to be heated by combine flue gas.




Figure 4.14: Coil E 205




Figure 4.15: Gird Diagram with E 205

4.2.8 Coil E 204 B

Now heat exchanger between Combine Flue Gas and Boiler Feed Water is placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.16: Coil E 204 B




Figure 4.17: Gird Diagram with E 204 B

4.2.9 Coil E 206

Now heat exchanger between Combine Flue Gas and Boiler Feed Water is placed. Heat exchanger is defined by providing supply or target temperatures of the streams exchanging heat.




Figure 4.18: Coil E 206




Figure 4.19: Gird Diagram with E 206

This is the completely satisfied heat exchanger network diagram for existing process.

4.2.9 Existing Heat Exchanger Network Grid Diagram

Following is the completely satisfied Grid Diagram for existing heat exchanger network:




Figure 4.20: Existing Heat Exchanger Network Grid Diagram

4.2.10 High Pressure Steam Production in Coil E 205

Currently the production High Pressure Steam is 63340 kilograms per hour.




Figure 4.21: High Pressure Steam Mass Flowrate

4.3 Analysis of the Existing Process

Detail analysis of the existing process is performed to identify different possible sources of heat recovery. For this, soft and fix data has to be identified. In this process, outlet temperature of coil E 205 has to be kept constant that is 336 °C as it directly affect the pressure of steam

being generated. Hence it is a fix data. On the other hand, stack temperature of the flue gas is soft data and can easily be changed by using Plus/Minus Principle. However, it cannot be reduce to less than sulphur dioxide dew point i.e. 120 °C. If the flue gas is released near sulphur dioxide dew point then it will not only be corrosive for the coils and shell as they are made up of carbon steel but flue gas will also cause acid rain. Hence it is harmful for both, the plant and the environment.

While reducing the temperature of the flue gas, following conditions must be considered.

- No temperature crossover occur between the streams.
- Approach temperature condition should not be violated in any heat exchangers.




Figure 4.22: Process Flow Diagram for Existing Process

Coils being heated by Combine Flue Gas effects the coils heated by Primary Reformer Flue Gas. Number of new cases are designed for the Combine Flue Gas portion using Aspen Energy Analyzer and most suitable case is then selected.

4.3.1 Case 1

In case 1, new pre heater is added to heat Process Air using Combine Flue Gas. Temperature of Combine Flue Gas was reduced from 336 °C to 190.7 °C while Process Air is heated from 177 °C to 293 °C and Natural and Recycle Gas is heated to 319 °C.

| Name | Inlet T [C] | Outlet T [C] | MCp [kJ/C-h] | Enthalpy [kJ/h] | Segm. | HTC [kJ/h-m2-C] | Flowrate [kg/h] | Effective Cp [kJ/kg-C] | DT Cont. [C] |
|-------------|-------------|--------------|--------------|-----------------|-------|-----------------|-----------------|------------------------|--------------|
| C FG | 336.0 | 190.9 | 3.816e+005 | 5.537e+007 | | 1218.00 | ---- | ---- | 27.0 |
| Process Air | 177.0 | 293.0 | 4.860e+004 | 5.638e+006 | | 414.00 | ---- | ---- | 27.0 |
| NG + RG | 41.9 | 319.0 | 7.920e+004 | 2.195e+007 | | 419.00 | ---- | ---- | 27.0 |
| BFW | 110.0 | 136.0 | 1.069e+006 | 2.780e+007 | | 20598.00 | ---- | ---- | 27.0 |
| **New** | | | | | | | | | |

Figure 4.23: Case 1-Streams Data




Figure 4.24: Case 1-Grid Diagram




Figure 4.25: Case 1-Coil E 202 B




Figure 4.26: Case 1-Coil E 204 B




Figure 4.27: Case 1-Coil E 206

Although temperature of the Flue Gas is significantly reduced, the areas of the exchangers came to be quite large making the case impractical to apply.

4.3.2 Case 2

In case 2, new pre heater to heat Process Air and heating Natural and Recycle Gas in two parts using Combine Flue Gas. Temperature of Combine Flue Gas was reduced from 336 °C to 190.7 °C while Process Air is heated from 177 °C to 293 °C and Natural and Recycle Gas is heated to 319 °C.

| Name | Inlet T [C] | Outlet T [C] | MCp [kJ/C-h] | Enthalpy [kJ/h] | Segm. | HTC [kJ/h-m ² -C] | Flowrate [kg/h] | Effective Cp [kJ/kg-C] | DT Cont. [C] |
|-------------|-------------|--------------|--------------|-----------------|-------|------------------------------|-----------------|------------------------|--------------|
| C FG | 336.0 | 190.7 | 3.816e+005 | 5.545e+007 | | 720.00 | ---- | ---- | 27.0 |
| Process Air | 177.0 | 293.0 | 4.860e+004 | 5.638e+006 | | 414.30 | ---- | ---- | 27.0 |
| NG + RG | 41.9 | 320.0 | 7.920e+004 | 2.203e+007 | | 419.00 | ---- | ---- | 27.0 |
| BFW | 110.0 | 136.0 | 1.069e+006 | 2.780e+007 | | 20598.00 | ---- | ---- | 27.0 |
| ***New*** | | | | | | | | | |

Figure 4.28: Case 2-Streams Data




Figure 4.29: Case 2-Grid Diagram




Figure 4.30: Case 2-E 204 B




Figure 4.31: Case 2-E 202 B




Figure 4.32: Case 2-E 206




Figure 4.33: Case 2-E 204 C

Similar issue is faced in this case as the area of exchangers are too large to use them in real system.

4.3.3 Case 3

In case 3, new pre heater to heat Process Air using Combine Flue Gas is added. However, temperature of Combine Flue Gas was reduced from 336 °C to 202 °C while Process Air is heated from 177 °C to 300 °C and Natural and Recycle Gas is heated to 260 °C.

| Name | Inlet T [C] | Outlet T [C] | MCp [kJ/C-h] | Enthalpy [kJ/h] | Segm. | HTC [kJ/h-m2-C] | Flowrate [kg/h] | Effective Cp [kJ/kg-C] | DT Cont. [C] |
|-------------|-------------|--------------|--------------|-----------------|-------|-----------------|-----------------|------------------------|--------------|
| C FG | 336.0 | 202.2 | 3.816e+005 | 5.106e+007 | | 1218.00 | ---- | ---- | 27.0 |
| Process Air | 177.0 | 300.0 | 4.860e+004 | 5.978e+006 | | 414.30 | ---- | ---- | 27.0 |
| NG + RG | 41.9 | 260.0 | 7.920e+004 | 1.727e+007 | | 419.00 | ---- | ---- | 27.0 |
| BFW | 110.0 | 136.0 | 1.069e+006 | 2.780e+007 | | 20598.00 | ---- | ---- | 27.0 |
| **New** | | | | | | | | | |

Figure 4.34: Case 3-Streams Data




Figure 4.35: Case 3-Grid Diagram




Figure 4.36: Case 3-E 202 B




Figure 4.37: Case 3-E 204 B




Figure 4.38: Case 3-E 206

This is the post suitable case to apply new preheater for the Process Air as the areas estimated by Aspen Energy Analyzer of heat exchangers are also in practical range to design coils.

In the next chapter, the selected case will be applied to design new exchanger network and results will be calculated based on it.

Chapter 5

New Heat Exchanger Network

Based on the solution suggested in chapter 4, proposed heat exchanger network is designed for all the process streams. Later new process flow diagram is drawn followed by comparing the results of both existing and proposed networks.

5.1 New Heat Exchanger Network Design

5.1.1 Defining Process Streams

Entire data for the process streams is same as the previous one except that outlet temperature of Combine Flue Gas is reduced to 201 °C.

| Name | Inlet T [C] | Outlet T [C] | MCp [kJ/C-h] | Enthalpy [kJ/h] | Segm. | HTC [kJ/h-m2-C] | Flowrate [kg/h] | Effective Cp [kJ/kg-C] | DT Cont. [C] |
|-------------|-------------|--------------|--------------|-----------------|-------|-----------------|-----------------|------------------------|--------------|
| P FG | 990.0 | 626.4 | ... | 1.206e+008 | ... | ... | 2.529e+001 | ... | 27.0 |
| B FG | 805.0 | 497.0 | 9.421e+004 | 2.902e+007 | ... | 720.0 | 7.477e+000 | 1.260 | 27.0 |
| C FG | 597.0 | 201.0 | ... | 1.528e+008 | ... | ... | 3.276e+001 | ... | 27.0 |
| Process Gas | 390.0 | 532.0 | 3.562e+00E | 5.059e+007 | ... | 615.0 | 1.431e+001 | 2.490 | 27.0 |
| Process Air | 177.0 | 492.0 | 4.896e+004 | 1.542e+007 | ... | 414.0 | 4.576e+000 | 1.070 | 27.0 |
| BFW 1 | 319.0 | 375.0 | ... | 7.465e+007 | ... | ... | 2.554e+001 | ... | 27.0 |
| NG + RG | 41.9 | 418.0 | ... | 3.223e+007 | ... | ... | 3.921e+001 | ... | 27.0 |
| BFW | 110.0 | 136.0 | 1.071e+00E | 2.783e+007 | ... | 20598.0 | 2.580e+001 | 4.150 | 27.0 |
| ***New** | | | | | | | | | |

Figure 5.1: Modified Streams Data

5.1.2 Defining Utility Stream

Utility for the system same.

| Name | Inlet T [C] | Outlet T [C] | Cost Index [Cost/kJ] | Segm. | HTC [kJ/h-m2-C] | Target Load [kJ/h] | Effective Cp [kJ/kg-C] | Target Flowrate [kg/h] | DT Cont. [C] |
|--|-------------|--------------|----------------------|-------|-----------------|--------------------|------------------------|------------------------|--------------|
| HP Steam Generation - 110 Bar <empty> | 319.0 | 320.0 | -2.490e-006 | ... | 2.160e+004 | 9.501e+007 | 1500 | 6.334e+004 | Global |

Figure 5.2: Utility Stream

5.1.3 New Heat Exchanger Network

In this network, a new preheater for Process Air is added after coil E 205. Total number of heat exchangers in the network are nine now.




Figure 5.3: Modified Heat Exchanger Network

5.1.3.1 Coil E 201

No change in the conditions of this exchanger.




Figure 5.4: Coil E 201

5.1.3.2 Coil E 202 A

In this exchanger, inlet temperature of Process Air is now 300 °C instead of 177 °C while outlet temperature of Primary Reformer Flue Gas is dropped from 794 °C to 811 °C.




Figure 5.5: Coil E 202 A

5.1.3.3 Coil E 203

In this exchanger, conditions of the cold stream in same. However, inlet and outlet temperature of Primary Reformer Flue Gas are now 811 °C and 673 °C instead of 794 °C and 655 °C, respectively.




Figure 5.6: Coil E 203

5.1.3.4 Coil E 204 A

In this exchanger, inlet temperature of Natural and Recycle Gas is now 260 °C instead of 247 °C. Inlet and outlet temperature of Primary Reformer Flue Gas are changed from 655 °C and 604 °C to 673 °C and 626 °C, respectively.




Figure 5.7: Coil E 204 A

5.1.3.5 Coil F 202 A

No change in the conditions of this exchanger.




Figure 5.8: Coil F 202 A

5.1.3.6 Coil E 205

In this exchanger, due to increase in the temperature of Primary Reformer Flue Gas, Combine flue Gas temperature is increased from 580 °C to 597 °C. However outlet temperature of Combine Flue Gas is kept constant to 336 °C as it will affect the pressure of steam being generated.




Figure 5.9: Coil E 205

5.1.3.7 Coil E 202 B

This is the new exchanger in the system. The inlet and outlet temperature of Process Air are estimated in previous chapter that are 177 °C and 300 °C, respectively.




Figure 5.10: Coil E 202 B

5.1.3.8 Coil E 204 B

In this exchanger, outlet temperature of Natural and Recycle Gas is increased to 260 °C from 247 °C. Inlet and outlet temperature of Combine Flue Gas are now 320 °C and 275 °C instead of 336 °C and 294 °C, respectively.




Figure 5.11: Coil E 204 B

5.1.3.9 Coil E 206

In this exchanger, conditions of the cold stream in same. However, inlet and outlet temperature of Combine Flue Gas are now 275 °C and 201 °C instead of 294 °C and 220 °C, respectively.




Figure 5.12: Coil E 206

5.1.3.10 High Pressure Steam Production in Coil E 205

As a result of increased inlet temperature of Combine Flue Gas at coil E 205, production of High Pressure Steam is increased from 63340 kilograms per hour to 67770 kilograms per hour.




Figure 5.13: New High Pressure Steam Mass Flowrate

5.1.4 New Heat Exchanger Network Grid Diagram

Following is the completely satisfied Grid Diagram for new heat exchanger network:




Figure 5.14 New Heat Exchanger Grid Network Design

5.2 Comparison of Networks

Following tables shows comparison between existing and proposed heat exchanger network.

| Parameters | Existing Heat Exchanger Network | New Heat Exchanger Network |
|-----------------------------|---------------------------------|----------------------------|
| Stack Gas Temperature (°C) | 220 | 201 |
| HP Steam Production (kg/hr) | 63340 | 67770 |

Table 5-1: Comparison of New and Existing Heat Exchange Network

5.2 New Process Flow Diagram

Based on the new heat exchanger network, modified process flow diagram is drawn. In this diagram, coil E 202 B is added after coil E 205 to pre heat Process Air.




Figure 5.15: New Process Flow Diagram

5.3 Material and Energy Balance of New Process

After the new system is designed, material and energy balance on the modified process is performed.

5.3.1 Material Balance

As no reaction or mixing is take place, material balance of the modified process will remain same to that performed in chapter 3. However, due to addition of new coil and changing the temperatures of some of the streams, energy balance of the system will change and is shown in the next section.

5.3.2 Energy Balance

Reference Temperature = 25 °C

Balance on Natural and Recycle Gas Mixer

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | H_{In} (kJ/hr) |
|--------------------------|--------------|---------------------|---------------|---------------------|
| Natural Gas | 38240 | 1.92 | 38 | 954470.4 |
| Recycle Gas | 996 | 3.87 | 117 | 354615.84 |
| Natural & Recycle Gas | 39210 | 1.99 | 41.9 | 1318671.51 |

$$\Delta H_{In} = \Delta H_{Natural\ Gas} + \Delta H_{Recycle\ Gas}$$

$$\Delta H_{In} = 954470.4 + 354615.84$$

$$\Delta H_{In} = 1309086.24\text{ kJ/hr}$$

$$\Delta H_{Out} = 1318671.51\text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Desulphurized Gas and Process Steam Mixer

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | H _{In} (kJ/hr) |
|--------------------------------------|--------------|------------------------------|------------------------|----------------------------|
| Process Steam | 103950 | 2.52 | 380 | 92993670 |
| Desulphurized Gas | 39210 | 2.42 | 413 | 36816621.6 |
| Process Steam & Desulphurized Gas | 143071 | 2.49 | 390 | 130030078.4 |

$$\Delta H_{In} = \Delta H_{Process\ steam} + \Delta H_{Desulphurized\ Gas}$$

$$\Delta H_{In} = 92993670 + 36816621.6$$

$$\Delta H_{In} = 129810291.6 \text{ kJ/hr}$$

$$\Delta H_{Out} = 130030078 \text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Primary Reformer Flue Gas and Boiler Flue Gas Mixer

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | H _{In} (kJ/hr) |
|---------------------------------|--------------|------------------------------|------------------------|----------------------------|
| Primary Reformer Flue Gas | 252861 | 1.3 | 626 | 197560325 |
| Boiler Flue Gas | 74772 | 1.26 | 497 | 44468452.52 |
| Combined Flue Gas | 327633 | 1.19 | 597 | 223013230.4 |

$$\Delta H_{In} = \Delta H_{Primary\ Reformer\ Flue\ Gas} + \Delta H_{Boiler\ Flue\ Gas}$$

$$\Delta H_{In} = 197560325 + 444.68452.52$$

$$\Delta H_{In} = 271046327.1 \text{ kJ/hr}$$

$$\Delta H_{Out} = 223013230.4 \text{ kJ/hr}$$

$$\text{So, } \Delta H_{In} \cong \Delta H_{Out}$$

Balance on Coil E 201

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|---------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Process Gas | 143071 | 2.49 | 390 | 532 | 130030078.4 | 180617122.5 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 990 | 840 | 324534492.7 | 274088716.6 |

$$\text{Duty E 201} = Q_{E\ 201} = 12.06 \text{ Gcal/hr} = 50410800 \text{ kJ/hr}$$

For Process Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 180617122.5 - 130030078.4$$

$$Q = 50587044.18 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 201} \cong Q$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 324534492.7 - 274088716.6$$

$$Q = 50445776.07 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 201} \cong Q$$

Balance on Coil E 202 A

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|---------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Process Air | 45761 | 1.07 | 300 | 492 | 13465174.25 | 22866314.1 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 840 | 811 | 274088716.6 | 262348378.9 |

Duty E 202 A = $Q_{E\ 202\ A} = ?$

For Process Air,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 22866314.09 - 13465174.25$$

$$Q = 9401139.84\text{ kJ/hr}$$

$$\text{So, } Q_{E\ 202\ A} = Q = 9401139.84\text{ kJ/hr}$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 274088716.6 - 26234873.9$$

$$Q = 11740337.76\text{ kJ/hr}$$

$$\text{So, } Q_{E\ 202\ A} \cong Q$$

$$Q_{E\ 202\ A} = 2.25\text{ Gcal/hr}$$

Balance on Coil E 203

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|---------------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Steam from Steam Drum | 143071 | 2.49 | 319 | 348 | 316092803.5 | 345622277.2 |
| Primary Reformer Flue Gas | 252861 | 1.3 | 811 | 673 | 262348378.9 | 213010134.0 |

Duty E 203 = $Q_{E\ 203}$ = 10.9 Gcal/hr = 45562000 kJ/hr

For Steam from Steam Drum,

$$Q = \Delta H_{out} - \Delta H_{in}$$

$$Q = 345622277.2 - 316092803.5$$

$$Q = 29529473.77 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 203} \cong Q$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{in} - \Delta H_{out}$$

$$Q = 262348378.9 - 213010134$$

$$Q = 49338244.75 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 203} \cong Q$$

Balance on Coil E 204 A

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|---------------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Natural and Recycle Gas | 39210 | 2.2 | 260 | 418 | 18336556 | 33900966 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 673 | 626 | 213010134 | 197560325 |

Duty E 204 A = $Q_{E\ 204\ A} = ?$

For Natural and Recycle Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 33900966 - 18336556$$

$$Q = 15564409.5\ \text{kJ/hr}$$

$$\text{So, } Q_{E\ 204\ A} = Q = 15564409.5\ \text{kJ/hr}$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 213010134.1 - 197560325$$

$$Q = 15449809.11\ \text{kJ/hr}$$

$$\text{So, } Q_{E\ 204\ A} \cong Q$$

$$Q_{E\ 204\ A} = 3.72\ \text{Gcal/hr}$$

Balance on Coil F 202 A

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|--------------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Steam from Steam Drum | 255379 | 4.19 | 348 | 375 | 345622277 | 374513303 |
| Boiler Flue Gas | 74772 | 1.26 | 805 | 497 | 73486002 | 44468452 |

$$\text{Duty F 202 A} = Q_{F 202 A} = 6.93 \text{ Gcal/hr} = 28967400 \text{ kJ/hr}$$

For Steam from Steam Drum,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 374513303.5 - 345622277.2$$

$$Q = 28891026.27 \text{ kJ/hr}$$

$$\text{So, } Q_{F 202 A} \cong Q$$

For Boiler Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 73486002.5 - 44468452.52$$

$$Q = 29017549.53 \text{ kJ/hr}$$

$$\text{So, } Q_{F 202 A} \cong Q$$

Balance on Coil E 205

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|----------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Combined Flue Gas | 327633 | 1.19 | 597 | 336 | 223013230.4 | 118196881.1 |

$$\text{Duty E 205} = Q_{E\ 205} = 22.81 \text{ Gcal/hr} = 95345800 \text{ kJ/hr}$$

For Combined Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 216385214.9 - 118196881.1$$

$$Q = 104816349.4 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 205} \cong Q$$

Balance on Heat Exchanger E 202 B

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|----------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Process Air | 45761 | 1.07 | 177 | 300 | 7442569.04 | 13465174.25 |
| Combined Flue Gas | 327633 | 1.16 | 336 | 320 | 118196881.1 | 112116013 |

$$\text{Duty E 202 B} = Q_{E\ 202\ B} = ?$$

For Process Air,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 33900966 - 18336556$$

$$Q = 15564409.5 \text{ kJ/hr}$$

$$\text{So, } Q_{E\ 202\ B} = Q = 15564409.5 \text{ kJ/hr}$$

For Combine Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 213010134.1 - 197560325$$

$$Q = 15449809.11 \text{ kJ/hr}$$

$$\text{So, } Q_{E 202 B} \cong Q$$

$$Q_{E 202 B} = 3.72 \text{ Gcal/hr}$$

Balance on Coil E 204 B

| Stream | M (kg/hr) | c _p (kJ/kg °C) | T _s (°C) | T _T (°C) | H _{In} (kJ/hr) | H _{Out} (kJ/hr) |
|----------------------------------|--------------|------------------------------|------------------------|------------------------|----------------------------|-----------------------------|
| Natural and Recycle Gas | 39210 | 2.49 | 41.9 | 260 | 1318671.51 | 18336556.5 |
| Combined Flue Gas | 327633 | 1.16 | 320 | 275 | 112116013 | 94194487.5 |

$$\text{Duty E 204 B} = Q_{E 204 B} = ?$$

For Natural and Recycle Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 33900966 - 18336556$$

$$Q = 17017884.99 \text{ kJ/hr}$$

$$\text{So, } Q_{E 204 B} = Q = 17017884.99 \text{ kJ/hr}$$

For Combine Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 213010134.1 - 197560325$$

$$Q = 17921525.1 \text{ kJ/hr}$$

$$\text{So, } Q_{E 204 B} \cong Q$$

$$Q_{E 204 B} = 4.07 \text{ Gcal/hr}$$

Balance on Coil E 206

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | H_{In} (kJ/hr) | H_{Out} (kJ/hr) |
|----------------------|--------------|---------------------|---------------|---------------|---------------------|----------------------|
| Boiler Feed Water | 257959 | 4.2 | 110 | 136 | 92091363 | 119974151.3 |
| Combined Flue Gas | 327633 | 1.16 | 275 | 201 | 94194487.5 | 66312919.2 |

$$\text{Duty E 206} = Q_{E 206} = ?$$

For Natural and Recycle Gas,

$$Q = \Delta H_{Out} - \Delta H_{In}$$

$$Q = 33900966 - 18336556$$

$$Q = 27882788.31 \text{ kJ/hr}$$

$$\text{So, } Q_{E 206} = Q = 27882788.31 \text{ kJ/hr}$$

For Primary Reformer Flue Gas,

$$Q = \Delta H_{In} - \Delta H_{Out}$$

$$Q = 213010134.1 - 197560325$$

$$Q = 27881568.3 \text{ kJ/hr}$$

$$\text{So, } Q_{E 206} \cong Q$$

$$Q_{E 206} = 6.67 \text{ Gcal/hr}$$

After performing energy balance on the new system, it was determined that duty of some of the coils has changed. Design of these coils are given in details in the next chapter.

Chapter 6

Coils Designing

In the previous chapter, duty of the following coils were determined.

- E 202 A
- E 202 B
- E 204 A
- E 204 B
- E 206

In this chapter detail designing of these coils is performed.

6.1 Design Parameters

These coils are designed as the helical coil heat exchangers. For this purpose following parameters for each coil are calculated. Equations used to design these parameters are given along with them.

- **Heat Load (Q)**

$$\Delta H = Q = M \times c_p(T_S - T_T) = C_P (T_S - T_T)$$

- **Overall Heat Transfer Coefficient (U)**

$$\frac{1}{U} = \frac{1}{h_{Hot}} + \frac{1}{h_{Cold}}$$

- **Log Mean Temperature Difference (ΔT_{LM})**

$$\Delta T_{LM} = \frac{(T_{Hot S} - T_{Cold T}) - (T_{Hot T} - T_{Cold S})}{\ln \frac{(T_{Hot S} - T_{Cold T})}{(T_{Hot T} - T_{Cold S})}}$$

- **Area (A)**

$$A = \frac{Q}{U \times \Delta T_{LM}}$$

- **Length (L)**

$$L = \frac{A}{\pi \times d_o}$$

- **Pitch (p)**

$$p = 1.5 \times d_o$$

- **Number of Turns (N)**

$$N = \frac{L}{\sqrt{(2\pi \times R)^2 + p^2}}$$

Where following factors are known

- Outside Diameter of Coil (d_o)
- Helix Radius (R)
- Mass flowrate of streams passing through coils (M)
- Specific Heat Capacity of streams passing through coils (c_p)
- Streams Supply and Target Temperatures
- Heat transfer coefficient of Hot Fluid (h_{hot})
- Heat transfer coefficient of Hot Fluid (h_{cold})

6.2 Designing of Coils

6.2.1 Coil E 202 A

In coil E 202 A, Process Air is heated by Primary Reformer Flue Gas. Following information is known.

Outside Diameter of Coil (d_o) = 88.9 mm

Helix Radius (R) = 1.15 m

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | h (W/m² °C) |
|------------------------------|----------------------|--|----------------------------------|----------------------------------|-----------------------------------|
| Process Air | 45761 | 1.07 | 300 | 492 | 115 |
| Primary Reformer Flue Gas | 252861 | 1.31 | 840 | 811 | 200 |

$$C_{P\ Cold} = 45761 \times 1.07/3600$$

$$C_{P\ Cold} = 13.6\ kW/^{\circ}C$$

$$Q = 13.6 \times (492 - 300)$$

$$Q = 2611.4\ kW$$

$$\frac{1}{U} = \frac{1}{200} + \frac{1}{115}$$

$$U = 73.02\ W/m^2/^{\circ}C$$

$$\Delta T_{LM} = \frac{(840 - 492) - (811 - 300)}{\ln \frac{(840 - 492)}{(811 - 300)}}$$

$$\Delta T_{LM} = 424.3^{\circ}C$$

$$A = \frac{2611.4 \times 1000}{73.02 \times 424.3}$$

$$A = 84.3\ m^2$$

$$L = \frac{84.3}{\pi \times (88.9/1000)}$$

$$L = 302\ m$$

$$p = 1.5 \times (88.9/1000)$$

$$p = 0.133$$

$$N = \frac{302}{\sqrt{(2\pi \times 1.15)^2 + 0.133^2}}$$

$$N = 42$$

6.2.2 Coil E 202 B

In coil E 202 B, Process Air is heated by Combine Flue Gas. Following information is known.

Outside Diameter of Coil (d_o) = 114.3 mm

Helix Radius (R) = 1.48 m

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | h (W/m ² °C) |
|------------------|--------------|---------------------|---------------|---------------|------------------------------|
| Process Air | 45761 | 1.07 | 177 | 300 | 115 |
| Combine Flue Gas | 327633 | 1.18 | 336 | 320 | 338 |

$$C_{P\ Cold} = 45761 \times 1.07/3600$$

$$C_{P\ Cold} = 13.6\ kW/°C$$

$$Q = 13.6 \times (300 - 177)$$

$$Q = 1673\ kW$$

$$\frac{1}{U} = \frac{1}{338} + \frac{1}{115}$$

$$U = 85.8\ W/m^2°C$$

$$\Delta T_{LM} = \frac{(336 - 300) - (320 - 177)}{\ln \frac{(336 - 300)}{(320 - 177)}}$$

$$\Delta T_{LM} = 77.57\ °C$$

$$A = \frac{1673 \times 1000}{77.57 \times 85.81}$$

$$A = 251.34\ m^2$$

$$L = \frac{251.34}{\pi \times (114.3/1000)}$$

$$L = 700\ m$$

$$p = 1.5 \times (114.3/1000)$$

$$p = 0.171$$

$$N = \frac{700}{\sqrt{(2\pi \times 1.48)^2 + 0.171^2}}$$

$$N = 75$$

6.2.3 Coil E 204 A

In coil E 204 A, Natural and Recycle Gas is heated by Primary Reformer Flue Gas. Following information is known.

Outside Diameter of Coil (d_o) = 88.9 mm

Helix Radius (R) = 1.15 m

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | h (W/m ² °C) |
|---------------------------|--------------|---------------------|---------------|---------------|----------------------------|
| Natural and Recycle Gas | 39210 | 2.18 | 260 | 418 | 116.4 |
| Primary Reformer Flue Gas | 252861 | 1.33 | 673 | 626 | 200 |

$$C_{P\ Cold} = 39210 \times 2.18/3600$$

$$C_{P\ Cold} = 23.72\ kW/°C$$

$$Q = 23.72 \times (418 - 260)$$

$$Q = 4164\ kW$$

$$\frac{1}{U} = \frac{1}{200} + \frac{1}{116.4}$$

$$U = 73.58\ W/m^2°C$$

$$\Delta T_{LM} = \frac{(673 - 418) - (626 - 260)}{\ln \frac{(673 - 418)}{(626 - 260)}}$$

$$\Delta T_{LM} = 307.16\ °C$$

$$A = \frac{4164 \times 1000}{307.2 \times 73.58}$$

$$A = 184.2\ m^2$$

$$L = \frac{184.2}{\pi \times (88.9/1000)}$$

$$L = 660\ m$$

$$p = 1.5 \times (88.9/1000)$$

$$p = 0.133$$

$$N = \frac{660}{\sqrt{(2\pi \times 1.15)^2 + 0.133^2}}$$

$$N = 91$$

6.2.4 Coil E 204 B

In coil E 204 B, Natural and Recycle Gas is heated by Combine Flue Gas. Following information is known.

Outside Diameter of Coil (d_o) = 114.3 mm

Helix Radius (R) = 1.48 m

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | h (W/m ² °C) |
|-------------------------|--------------|---------------------|---------------|---------------|------------------------------|
| Natural and Recycle Gas | 39210 | 2.18 | 41.9 | 260 | 116.4 |
| Combine Flue Gas | 327633 | 1.18 | 320 | 275 | 338 |

$$C_{P \text{ cold}} = 39210 \times 2.18/3600$$

$$C_{P \text{ cold}} = 23.72 \text{ kW/}^\circ\text{C}$$

$$Q = 23.72 \times (260 - 41.9)$$

$$Q = 4789 \text{ kW}$$

$$\frac{1}{U} = \frac{1}{338} + \frac{1}{116.4}$$

$$U = 86.6 \text{ W/m}^2\text{°C}$$

$$\Delta T_{LM} = \frac{(320 - 260) - (275 - 41.9)}{\ln \frac{(320 - 260)}{(275 - 41.9)}}$$

$$\Delta T_{LM} = 127.55 \text{ }^\circ\text{C}$$

$$A = \frac{4789 \times 1000}{86.6 \times 127.55}$$

$$A = 433.63 \text{ m}^2$$

$$L = \frac{433.63}{\pi \times (114.3/1000)}$$

$$L = 1208 \text{ m}$$

$$p = 1.5 \times (114.3/1000)$$

$$p = 0.171$$

$$N = \frac{1208}{\sqrt{(2\pi \times 1.48)^2 + 0.171^2}}$$

$$N = 130$$

6.2.5 Coil E 206

In coil E 206, Boiler Feed Water is heated by Combine Flue Gas. Following information is known.

Outside Diameter of Coil (d_o) = 114.3 mm

Helix Radius (R) = 1.48 m

| Stream | M (kg/hr) | c_p (kJ/kg °C) | T_s (°C) | T_T (°C) | h (W/m ² °C) |
|-------------------|--------------|---------------------|---------------|---------------|---------------------------------|
| Boiler Feed Water | 252861 | 4.15 | 110 | 136 | 5722 |
| Combine Flue Gas | 327633 | 1.18 | 320 | 201 | 338 |

$$C_{P \text{ cold}} = 252861 \times 12.8/3600$$

$$C_{P \text{ cold}} = 297.01 \text{ kW}/^\circ\text{C}$$

$$Q = 297.01 \times (136 - 110)$$

$$Q = 7730 \text{ kW}$$

$$\frac{1}{U} = \frac{1}{338} + \frac{1}{5722}$$

$$U = 319.15 \text{ W}/\text{m}^2\text{°C}$$

$$\Delta T_{LM} = \frac{(275 - 136) - (201 - 110)}{\ln \frac{(275 - 136)}{(201 - 110)}}$$

$$\Delta T_{LM} = 113.3 \text{ } ^\circ\text{C}$$

$$A = \frac{7730 \times 1000}{319.15 \times 113.3}$$

$$A = 213.76 \text{ m}^2$$

$$L = \frac{213.76}{\pi \times (114.3/1000)}$$

$$L = 595.7 \text{ m}$$

$$p = 1.5 \times (114.3/1000)$$

$$p = 0.171$$

$$N = \frac{595.7}{\sqrt{(2\pi \times 1.48)^2 + 0.171^2}}$$

$$N = 64$$

6.3 Coil Design Summary

Following table shows the summary of coil design:

| Parameters | E 202 A | E 202 B | E 204 A | E 204 B | E 206 |
|---|---------|---------|---------|---------|-------|
| Heat Load (kW) | 2611.4 | 1673 | 4163.8 | 4788.8 | 7730 |
| Hot Fluid T_s (°C) | 840 | 336 | 673 | 320 | 275 |
| Hot Fluid T_T (°C) | 811 | 320 | 626 | 275 | 201 |
| Cold Fluid T_s (°C) | 300 | 177 | 260 | 41.9 | 110 |
| Cold Fluid T_T (°C) | 492 | 300 | 418 | 260 | 136 |
| Hot Fluid h (W/m ² °C) | 200 | 338 | 200 | 338 | 338 |
| Cold Fluid h (W/m ² °C) | 115 | 115 | 116.4 | 116.4 | 5722 |
| Overall Heat Transfer Coefficient U (W/m ² °C) | 73.02 | 85.81 | 73.58 | 86.58 | 319 |
| LMTD (°C) | 424.29 | 77.57 | 307.16 | 127.55 | 113 |
| Area (m ²) | 84.29 | 251.34 | 184.24 | 433.63 | 213.8 |
| Coil Outer Diameter d_o (mm) | 88.9 | 114.3 | 88.9 | 114.3 | 114.3 |
| Helix Radius R (m) | 1.15 | 1.48 | 1.15 | 1.48 | 1.48 |
| Length L (m) | 301.97 | 700.30 | 660.00 | 1208.2 | 595.6 |
| Pitch p (m) | 0.133 | 0.171 | 0.133 | 0.171 | 0.171 |
| Number of Turns (N) | 42 | 75 | 91 | 130 | 64 |

Table 6-1: Coils Design Summary

6.4 Area Targeting

To calculate the minimum area requirement for the heat exchanger network, balanced combine composite curve is used. Balanced combine composite curve is same as combine composite curve, in addition to it also includes utility streams. By including utility streams, both hot and cold composite curve are in energy balance with one another. First minimum cold utility requirement is calculated using problem table algorithm for the new stream data.

6.4.1 Stream Data

Modified streams data is as followed:

| Process Streams | M (kg/hr) | c_p (kJ/kg °C) | C_p (kW/°C) | T_s (°C) | T_T (°C) | ΔH (kJ/hr) | h (W/m ² °C) |
|---------------------------|-----------|------------------|---------------|------------|------------|--------------------|---------------------------|
| Natural & Recycle Gas | 39210 | 2.18 | 23.7 | 41 | 418 | 8943 | 116.4 |
| Process Air | 45761 | 1.07 | 13.6 | 177 | 492 | 4280 | 115.0 |
| Process Gas | 143071 | 2.67 | 106 | 400 | 532 | 14026 | 170.8 |
| Steam from Steam Drum | 255379 | 5.22 | 370 | 319 | 375 | 20736 | 70.0 |
| BFW | 257959 | 4.15 | 297 | 110 | 136 | 7722 | 5721 |
| Primary Reformer Flue Gas | 252861 | 1.31 | 91.9 | 990 | 626 | 35483 | 200.0 |
| Boiler Flue Gas | 74772 | 1.26 | 26.1 | 805 | 497 | 8060 | 200.0 |
| Combine Flue Gas | 327633 | 1.18 | 107 | 597 | 201 | 38693 | 338.3 |

Table 6-2: Modified Streams Data

Streams shifted temperatures are as followed:

| Process Streams | T_s (°C) | T_T (°C) | Stream Type | Shift T_s (°C) | Shift T_T (°C) |
|------------------------------|-------------------------------|-------------------------------|------------------------|-------------------------------------|-------------------------------------|
| Natural & Recycle Gas | 41 | 418 | Cold | 54.5 | 431.5 |
| Process Air | 177 | 492 | Cold | 190.5 | 505.5 |
| Process Gas | 400 | 532 | Cold | 413.5 | 545.5 |
| Steam | 319 | 375 | Cold | 332.5 | 388.5 |
| BFW | 110 | 136 | Cold | 123.5 | 149.5 |
| Primary Reformer Flue Gas | 990 | 629 | Hot | 976.5 | 612.5 |
| Boiler Flue Gas | 805 | 497 | Hot | 791.5 | 483.5 |
| Combine Flue Gas | 597 | 201 | Hot | 583.5 | 187.5 |

Table 6-3: Modified Streams Shifted Temperatures

$$\Delta T_{min} = 27^{\circ}\text{C}$$

6.4.2 Problem Table Algorithm

To determine minimum cold utility requirement, problem table algorithm is developed for modified streams data.

| Shift Temperature (°C) | Interval | $T_{(i+1)}-T_i$ (°C) | $C_{P\ net}$ (kW/°C) | dH (kW) | | Infeasible/ Feasible Cascade |
|------------------------|----------|----------------------|----------------------|---------|-------|------------------------------|
| 976.5 | | | | | Pinch | 0 |
| | 1 | 185 | 91.9 | 17001.5 | S | |
| 791.5 | | | | | | 17002 |
| | 2 | 179 | 118.1 | 21139.9 | S | |
| 612.5 | | | | | | 38141 |
| | 3 | 29 | 26.2 | 759.8 | S | |
| 583.5 | | | | | | 38901 |
| | 4 | 38 | 133.7 | 5080.6 | S | |
| 545.5 | | | | | | 43982 |
| | 5 | 40 | 27.4 | 1096.0 | S | |
| 505.5 | | | | | | 45078 |
| | 6 | 22 | 13.8 | 303.6 | S | |
| 483.5 | | | | | | 45381 |
| | 7 | 52 | -12.4 | -644.8 | D | |
| 431.5 | | | | | | 44737 |
| | 8 | 28 | -36.12 | -1011.4 | D | |
| 403.5 | | | | | | 43725 |
| | 9 | 15 | 70.18 | 1052.7 | S | |
| 388.5 | | | | | | 44778 |
| | 10 | 56 | -300.1 | -16807 | D | |
| 332.5 | | | | | | 27971 |
| | 11 | 142 | 70.18 | 9965.56 | S | |
| 190.5 | | | | | | 37937 |
| | 12 | 3 | 83.78 | 251.34 | S | |
| 187.5 | | | | | | 38188 |
| | 13 | 38 | -23.72 | -901.36 | D | |
| 149.5 | | | | | | 37287 |
| | 14 | 26 | -131.2 | -3411.7 | D | |
| 123.5 | | | | | | 33875 |
| | 15 | 68.1 | -23.72 | -1615.3 | D | |
| 55.4 | | | | | | 32260 |

Table 6-4: Problem Table Algorithm for Modified Data

Hence, minimum cold utility requirement = 32260 kW

6.4.3 Balanced Combine Composite Curve

For hot balance composite curve, following tables are used.

| Process Stream | T_S (°C) | T_T (°C) | C_P (kW/°C) | h (W/m² °C) |
|---------------------------|-------------------------------|-------------------------------|----------------------------------|-----------------------------------|
| Primary Reformer Flue Gas | 990 | 626 | 91.9 | 200 |
| Boiler Flue Gas | 805 | 497 | 26.2 | 200 |
| Combine Flue Gas | 597 | 201 | 107.5 | 338.3 |

Table 6-5: Modified Hot Streams Data

| Actual Temperature (°C) | Interval | T_(i+1)-T_i (°C) | ΣC_P Hot (kW/°C) | Heat Load (kW) | Total Heat Flow (kW) |
|------------------------------------|-----------------|---|---------------------------------------|---------------------------|---------------------------------|
| 201 | | | | | 0 |
| 497 | 1 | 296 | 107.5 | 31820 | 31820 |
| 597 | 2 | 100 | 133.7 | 13370 | 45190 |
| 626 | 3 | 29 | 26.2 | 759.8 | 45949.8 |
| 805 | 4 | 179 | 118.1 | 21140 | 67089.8 |
| 990 | 5 | 185 | 91.9 | 170002 | 84091.2 |

Table 6-6: Data for Hot Balance Composite Curve

For cold balance composite curve,

| Process Stream | T_s (°C) | T_T (°C) | C_p (kW/°C) | h (W/m² °C) |
|-----------------------|-------------------------------|-------------------------------|----------------------------------|-----------------------------------|
| Natural & Recycle Gas | 41.9 | 418 | 23.72 | 116.4 |
| Process Air | 177 | 492 | 13.6 | 115 |
| Process Gas | 390 | 532 | 106.3 | 170.8 |
| Steam from Steam Drum | 319 | 375 | 370.3 | 70.0 |
| Boiler Feed Water | 110 | 136 | 107.5 | 5721 |
| HP Steam Generation | 319 | 320 | 32259.7 | 6000 |

Table 6-7: Modified Cold Streams Data

| Actual Temperature (°C) | Interval | T_(i+1)-T_i (°C) | ΣC_p cold (kW/°C) | Heat Load (kW) | Total Heat Flow (kW) |
|------------------------------------|-----------------|---|--|---------------------------|---------------------------------|
| 41.9 | | | | | 0 |
| 110 | 1 | 68.1 | 23.72 | 1615.332 | 1615.3 |
| 136 | 2 | 26 | 131.22 | 3411.72 | 5027.052 |
| 177 | 3 | 41 | 23.72 | 972.52 | 5999.572 |
| 319 | 4 | 142 | 37.32 | 5299.44 | 11299.01 |
| 320 | 5 | 1 | 26935.6 | 32667.32 | 43966.33 |
| 375 | 6 | 55 | 407.6 | 22419.1 | 66385.43 |
| 390 | 7 | 15 | 37.32 | 559.8 | 66945.23 |
| 418 | 8 | 28 | 143.6 | 4021.36 | 70966.59 |
| 492 | 9 | 74 | 119.9 | 8872.6 | 79839.19 |
| 532 | 10 | 40 | 106.3 | 4252 | 84091.19 |

Table 6-8: Data for Cold Balance Composite Curve

Now plot temperature against heat flow to obtain balance combine composite curve.




Figure 6.1: Balance Combine Composite Curve

Bath algorithm is used to determine minimum heat transfer area for the heat exchanger network.

6.4.4 Bath Algorithm

In bath algorithm, first the values of total heat flow for both hot and cold streams are arranged in ascending order and any repeated value is omitted. Corresponding value of temperatures for hot and cold composite curve are calculated by using following relation if it is unknown for the enthalpy interval.

For hot curve,

$$T_{H,row\ q} = T_{H,row\ r} - (\Delta H_{row\ r} - \Delta H_{row\ q}) / \Sigma C_{P\ H,row\ r}$$

Where

$T_{H,row\ q}$ = Unknown value of hot curve temperature in row q

$T_{H,row\ r}$ = Known value of hot curve temperature in row r

$\Delta H_{row\ r}$ = Heat load in row r

$\Delta H_{row\ q}$ = Heat load in row q

$\Sigma C_{P,H, row r}$ = Summation of hot streams heat capacity in row r

For cold curve,

$$T_{C, row q} = T_{C, row r} - (\Delta H_{row r} - \Delta H_{row q}) / \Sigma C_{P,C, row r}$$

Where

$T_{C, row q}$ = Unknown value of cold curve temperature in row q

$T_{C, row r}$ = Known value of cold curve temperature in row r

$\Delta H_{row r}$ = Heat load in row r

$\Delta H_{row q}$ = Heat load in row q

$\Sigma C_{P,C, row r}$ = Summation of cold streams heat capacity in row r

Then compute $\Sigma (C_P/h)_h$ and $\Sigma (C_P/h)_c$ for each enthalpy interval.

After that calculate $\Sigma (Q/h)_n$ for each interval using:

$$\Sigma (Q/h)_n = \Delta T_{H,n} \times \Sigma (C_P/h)_h + \Delta T_{C,n} \times \Sigma (C_P/h)_c$$

Calculate log mean temperature different (ΔT_{LM}) for each interval and divide $\Sigma (Q/h)_n$ with it to calculate the area for these intervals. Sum of the areas of all these intervals will give the total area required for heat exchange.

| In | Q _n (kW) | T _{Hn} (°C) | T _{Cn} (°C) | ΣC _{P H/C} | Σ(C _{P/h}) Hot | Σ(C _{P/h}) Cold | Σ(Q/h) _n | ΔT _{lm} (°C) | A _n (m ²) |
|----|------------------------|-------------------------|-------------------------|---------------------|-----------------------------|------------------------------|---------------------|--------------------------|-------------------------------------|
| | 0 | 201 | 41.9 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1 | 1615 | 216 | 110 | 23.72 | 317.7 | 203.7 | 18652 | 130 | 142 |
| 2 | 5027 | 247 | 136 | 131.2 | 317.7 | 222.5 | 15871 | 108 | 145 |
| 3 | 5999 | 303 | 177 | 23.72 | 317.7 | 203.7 | 26186 | 119 | 219 |
| 4 | 11299 | 343.5 | 319 | 37.32 | 317.7 | 322 | 58325 | 62 | 936 |
| 5 | 31820 | 497 | 319.5 | 107.5 | 317.7 | 10988 | 54805 | 77 | 709.3 |
| 6 | 43966 | 587.8 | 320 | 26935 | 448.7 | 10988 | 45724 | 219 | 208.2 |
| 7 | 45190 | 597 | 323 | 133.7 | 448.7 | 5612 | 20868 | 270 | 77 |
| 8 | 45949 | 626 | 3245 | 26.2 | 131 | 5612 | 14262 | 287 | 49.6 |
| 9 | 66385 | 800 | 375 | 407.5 | 590.5 | 5612 | 384240 | 359 | 1068 |
| 10 | 66945 | 804 | 390 | 37.32 | 590.5 | 322 | 7132 | 419 | 17 |
| 11 | 67089 | 805 | 394 | 143.6 | 590.5 | 944 | 4249 | 412 | 10.3 |
| 12 | 70966 | 866 | 418 | 118.1 | 459.5 | 944 | 51061 | 429 | 118.8 |
| 13 | 79839 | 950 | 492 | 119.9 | 459.5 | 740 | 93159 | 453 | 205.5 |
| 14 | 84091 | 990 | 532 | 106.3 | 459.5 | 622 | 43274 | 458 | 94.5 |

Table 6-9: Area Targeting

Total area is 4004 m².

6.3.4 Area Comparison

Area of current installed coils and newly designed coils is as followed:

| Coils | Area (m ²) |
|-------------------|------------------------|
| E 201 | 336 |
| E 202 A | 84.3 |
| E 203 | 629 |
| E 204 A | 184.2 |
| F 202 A | 587 |
| E 205 | 940 |
| E 202 B | 251.3 |
| E204 B | 433.63 |
| E 206 | 213.8 |
| Total Area | 3659.23 |

Table 6-10: Area of Coils

$$\text{Area Target Achieved} = \frac{3660}{4004} \times 100\% = 91.5\%$$

Chapter 7


Economic Analysis

7.1 Cost of Coils

Coils are made up of carbon steel. Cost of coils is determine by using following graphs and lag factors. Calculation for fixed capital is shown below:

| Equipment | Area (m²) | Equipment Cost (\$) |
|--|-----------------------------|----------------------------|
| E 202 A | 84.29 | 30000 |
| E 202 B | 251.34 | 61000 |
| E 204 A | 184.24 | 49000 |
| E 204 B | 433.63 | 85000 |
| E 206 | 213.76 | 52000 |
| Purchas Cost of Equipment | PCE (\$) | 277,000 |
| f ₁ Equipment erection | 0.4 | |
| f ₂ Piping | 0.7 | |
| f ₃ Instrumentation | 0.2 | |
| f ₄ Electrical | 0.1 | |
| f ₅ Buildings | none required | |
| f ₆ Utilities | not applicable | |
| f ₇ Storages | not applicable | |
| f ₈ Site development | not applicable | |
| f ₉ Ancillary buildings | none required | |
| Total Physical Plant Cost | PPC (\$) | 664,800 |
| f ₁₀ Design and Engineering | 0.3 | |
| f ₁₁ Contractor's Fee | none | |
| f ₁₂ Contingencies | 0.1 | |
| | Fixed Capital (\$) | 930,720 |

Table 7-1: Fixed Capital (\$)



| Materials | | Pressure factors | Type factors |
|----------------|-----------------|------------------|------------------------|
| Shell | Tubes | | |
| ① Carbon steel | Carbon steel | 1–10 bar × 1.0 | Floating head × 1.0 |
| ② C.S. | Brass | 10–20 × 1.1 | Fixed tube sheet × 0.8 |
| ③ C.S. | Stainless steel | 20–30 × 1.25 | U tube × 0.85 |
| ④ S.S. | S.S. | 30–50 × 1.3 | Kettle × 1.3 |
| | | 50–70 × 1.5 | |

Figure 6.3a, b. Shell and tube heat exchangers. Time base mid-2004
Purchased cost = (bare cost from figure) × Type factor × Pressure factor

Figure 7.1: Cost to Heat Transfer Area Graph

7.2 Economic Analysis

Following tables shows the cost saving due to extra production of steam and payback period of project by introducing these new coils.

| | |
|--|----------------------------------|
| Total Area of Coils | 1167.26 m ² |
| Capital Cost of Coils | \$ 930,720 |
| Surplus HP Steam Generated | 4430 kg/hr |
| Cost Saved Per Annum by Surplus HP Steam | \$ 4.51x10 ⁵ per year |
| Pay Back Period | 2.06 years |

Table 7-2: Economic Analysis

*Cost of steam is approximately \$12 per ton.

So, the payback period of this project is 2.06 years so it is feasible to apply these modifications.

Chapter 8

Aspen HYSYS Simulation

For the verification of proposed design, it was simulated on Aspen HYSYS. Detailed simulation of the process is as followed.

8.1 HYSYS Simulation

8.1.1 Components

Following list of components was selected from HYSYS databank.

| Source Databank: HYSYS | | |
|------------------------|----------------|-------|
| Component | Type | Group |
| Oxygen | Pure Component | |
| Hydrogen | Pure Component | |
| Nitrogen | Pure Component | |
| CO | Pure Component | |
| CO2 | Pure Component | |
| Argon | Pure Component | |
| Methane | Pure Component | |
| Ethane | Pure Component | |
| H2O | Pure Component | |

Figure 8.1: Components

8.1.2 Fluid Package

Peng Robinson is selected as fluid package for simulation as only non-polar gases area involve.

| Fluid Package | Component List | Property Package | Status |
|---------------|--------------------------------------|------------------|----------------|
| Basis-1 | Component List - 1 [HYSYS Databanks] | Peng-Robinson | Input Complete |

Figure 8.2: Fluid Package

8.1.3 Model




Figure 8.3: Simulation Model

8.1.4 Defined Streams

Following streams were defined on HYSYS.

Natural Gas

Material Stream: Natural Gas

| Worksheet | Stream Name | Natural Gas | Vapour Phase |
|-------------------|-------------------------------|-------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 38.00 | 38.00 |
| Composition | Pressure [kPa] | 3906 | 3906 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1869 | 1869 |
| Petroleum Assay | Mass Flow [kg/h] | 3.824e+004 | 3.824e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 93.87 | 93.87 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -8.710e+004 | -8.710e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 152.2 | 152.2 |
| Cost Parameters | Heat Flow [kJ/h] | -1.628e+008 | -1.628e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 4.409e+004 | 4.409e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.4: Natural Gas

Recycle Gas

Material Stream: Recycle Gas

| Worksheet | Stream Name | Recycle Gas | Vapour Phase |
|-------------------|-------------------------------|-------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 117.0 | 117.0 |
| Composition | Pressure [kPa] | 5005 | 5005 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 115.1 | 115.1 |
| Petroleum Assay | Mass Flow [kg/h] | 995.7 | 995.7 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 3.513 | 3.513 |
| User Variables | Molar Enthalpy [kJ/kgmole] | 1934 | 1934 |
| Notes | Molar Entropy [kJ/kgmole-C] | 110.0 | 110.0 |
| Cost Parameters | Heat Flow [kJ/h] | 2.227e+005 | 2.227e+005 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 2723 | 2723 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Figure 8.5: Recycle Gas

Natural & Recycle Gas

Material Stream: Natural+Recycle Gas

| Worksheet | Stream Name | Natural+Recycle Gas | Vapour Phase |
|-------------------|-------------------------------|---------------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 40.97 | 40.97 |
| Composition | Pressure [kPa] | 3906 | 3906 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1984 | 1984 |
| Petroleum Assay | Mass Flow [kg/h] | 3.924e+004 | 3.924e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 97.39 | 97.39 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -8.193e+004 | -8.193e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 151.3 | 151.3 |
| Cost Parameters | Heat Flow [kJ/h] | -1.625e+008 | -1.625e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 4.681e+004 | 4.681e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.6: Natural & Recycle Gas

Desulphurized Natural Gas

Material Stream: Desulphurized NG

| Worksheet | Stream Name | Desulphurized NG | Vapour Phase |
|-------------------|-------------------------------|------------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 413.0 | 413.0 |
| Composition | Pressure [kPa] | 3808 | 3808 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1984 | 1984 |
| Petroleum Assay | Mass Flow [kg/h] | 3.924e+004 | 3.924e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 97.39 | 97.39 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -6.561e+004 | -6.561e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 185.1 | 185.1 |
| Cost Parameters | Heat Flow [kJ/h] | -1.302e+008 | -1.302e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 4.681e+004 | 4.681e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.7: Desulphurized Natural Gas

Process Steam

Material Stream: Process Steam

Worksheet Attachments Dynamics

| Worksheet | Stream Name | Process Steam | Vapour Phase |
|-------------------|-------------------------------|---------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 380.0 | 380.0 |
| Composition | Pressure [kPa] | 3828 | 3828 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 5770 | 5770 |
| Petroleum Assay | Mass Flow [kg/h] | 1.040e+005 | 1.040e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 104.2 | 104.2 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -2.305e+005 | -2.305e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 169.6 | 169.6 |
| Cost Parameters | Heat Flow [kJ/h] | -1.330e+009 | -1.330e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 102.4 | 102.4 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.8: Process Steam

Process Gas

Material Stream: Process Gas

Worksheet Attachments Dynamics

| Worksheet | Stream Name | Process Gas | Vapour Phase |
|-------------------|-------------------------------|-------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 385.6 | 385.6 |
| Composition | Pressure [kPa] | 3808 | 3808 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 7754 | 7754 |
| Petroleum Assay | Mass Flow [kg/h] | 1.432e+005 | 1.432e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 201.5 | 201.5 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -1.883e+005 | -1.883e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 178.2 | 178.2 |
| Cost Parameters | Heat Flow [kJ/h] | -1.460e+009 | -1.460e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 189.0 | 189.0 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.9: Process Gas

Process Air

Material Stream: Process Air

| Worksheet | Attachments | Dynamics | |
|-------------------|-------------------------------|--------------------|--------------|
| Worksheet | Stream Name | Process Air | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 177.0 | 177.0 |
| Composition | Pressure [kPa] | 32.40 | 32.40 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1585 | 1585 |
| Petroleum Assay | Mass Flow [kg/h] | 4.581e+004 | 4.581e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 52.64 | 52.64 |
| User Variables | Molar Enthalpy [kJ/kgmole] | 3093 | 3093 |
| Notes | Molar Entropy [kJ/kgmole-C] | 173.9 | 173.9 |
| Cost Parameters | Heat Flow [kJ/h] | 4.901e+006 | 4.901e+006 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 3.744e+004 | 3.744e+004 |
| | Fluid Package | <i>Basis-1</i> | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.10: Process Air

Boiler Feed Water

Material Stream: BFW

| Worksheet | Attachments | Dynamics | |
|-------------------|-------------------------------|-------------------|---------------|
| Worksheet | Stream Name | BFW | Aqueous Phase |
| Conditions | Vapour / Phase Fraction | 0.0000 | 1.0000 |
| Properties | Temperature [C] | 110.0 | 110.0 |
| Composition | Pressure [kPa] | 1.383e+004 | 1.383e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.432e+004 | 1.432e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 2.580e+005 | 2.580e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 258.5 | 258.5 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -2.794e+005 | -2.794e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 73.05 | 73.05 |
| Cost Parameters | Heat Flow [kJ/h] | -4.000e+009 | -4.000e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 254.2 | 254.2 |
| | Fluid Package | <i>Basis-1</i> | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.11: Boiler Feed Water

Steam from Steam Drum

Material Stream: From Steam Drum

| Worksheet | Attachments | Dynamics | |
|-------------------|-------------------------------|------------------------|--------------|
| Worksheet | Stream Name | From Steam Drum | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 319.0 | 319.0 |
| Composition | Pressure [kPa] | 1.108e+004 | 1.108e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.418e+004 | 1.418e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 2.554e+005 | 2.554e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 255.9 | 255.9 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -2.368e+005 | -2.368e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 151.9 | 151.9 |
| Cost Parameters | Heat Flow [kJ/h] | -3.357e+009 | -3.357e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 251.7 | 251.7 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.12: Steam from Steam Drum

Primary Reformer Flue Gas

Material Stream: P FG from Reformer

| Worksheet | Attachments | Dynamics | |
|-------------------|-------------------------------|---------------------------|--------------|
| Worksheet | Stream Name | P FG from Reformer | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 990.0 | 990.0 |
| Composition | Pressure [kPa] | 1.100e+004 | 1.100e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 9040 | 9040 |
| Petroleum Assay | Mass Flow [kg/h] | 2.530e+005 | 2.530e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 302.9 | 302.9 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -4.538e+004 | -4.538e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 171.1 | 171.1 |
| Cost Parameters | Heat Flow [kJ/h] | -4.102e+008 | -4.102e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 2.130e+005 | 2.130e+005 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Figure 8.13: Primary Reformer Flue Gas

Boiler Flue Gas

Material Stream: B FG to F 202 A

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|-----------------|--------------|
| Worksheet | Stream Name | B FG to F 202 A | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 805.0 | 805.0 |
| Composition | Pressure [kPa] | 1.100e+004 | 1.100e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 2669 | 2669 |
| Petroleum Assay | Mass Flow [kg/h] | 7.481e+004 | 7.481e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 89.43 | 89.43 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -4.916e+004 | -4.916e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 164.8 | 164.8 |
| Cost Parameters | Heat Flow [kJ/h] | -1.312e+008 | -1.312e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 6.290e+004 | 6.290e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.14: Boiler Flue Gas

Combine Flue Gas

Material Stream: Combine FG

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|-------------|--------------|
| Worksheet | Stream Name | Combine FG | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 666.5 | 666.5 |
| Composition | Pressure [kPa] | 1.100e+004 | 1.100e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.171e+004 | 1.171e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 3.278e+005 | 3.278e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 392.4 | 392.4 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -5.662e+004 | -5.662e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 160.1 | 160.1 |
| Cost Parameters | Heat Flow [kJ/h] | -6.630e+008 | -6.630e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 2.759e+005 | 2.759e+005 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.15: Combine Flue Gas

8.1.5 Mixers

Now mixers are simulated in HYSYS.

MIX-100

The Natural Gas and Recycle Gas are mixed together in MIX-100 to produce mixture of Natural and Recycle Gas.




Figure 8.16: MIX-100 Design

The screenshot shows the 'Mixer: MIX-100' worksheet window. It features a 'Worksheet' tab with a sidebar containing 'Conditions', 'Properties', 'Composition', and 'PF Specs'. The main area displays a table of process parameters for the mixer. The table includes columns for 'Natural Gas', 'Recycle Gas', and 'Natural+Recycle'.

| Name | Natural Gas | Recycle Gas | Natural+Recycle |
|-------------------------------|-------------|-------------|-----------------|
| Vapour | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 38.00 | 117.0 | 40.97 |
| Pressure [kPa] | 3906 | 5005 | 3906 |
| Molar Flow [kgmole/h] | 1869 | 115.1 | 1984 |
| Mass Flow [kg/h] | 3.824e+004 | 995.7 | 3.924e+004 |
| Std Ideal Liq Vol Flow [m3/h] | 93.87 | 3.513 | 97.39 |
| Molar Enthalpy [kJ/kgmole] | -8.710e+004 | 1934 | -8.193e+004 |
| Molar Entropy [kJ/kgmole-C] | 152.2 | 110.0 | 151.3 |
| Heat Flow [kJ/h] | -1.628e+008 | 2.227e+005 | -1.625e+008 |

The window also includes 'Delete', 'OK', and 'Ignored' buttons at the bottom.

Figure 8.17: MIX-100 Worksheet

MIX-101

The streams; Process Steam and Desulphurized Natural Gas, are mixed together in MIX-101 to produce Process Gas.




Figure 8.18 MIX-101 Design

The screenshot shows the 'Worksheet' tab of the 'Mixer: MIX-101' window. The table below contains the following data:

| | Process Steam | Desulphurized N | Process Gas | |
|-------------------------------|---------------|-----------------|-------------|--------|
| Name | Vapour | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 380.0 | 413.0 | 385.6 | |
| Pressure [kPa] | 3828 | 3808 | 3808 | |
| Molar Flow [kgmole/h] | 5770 | 1984 | 7754 | |
| Mass Flow [kg/h] | 1.040e+005 | 3.924e+004 | 1.432e+005 | |
| Std Ideal Liq Vol Flow [m3/h] | 104.2 | 97.39 | 201.5 | |
| Molar Enthalpy [kJ/kgmole] | -2.305e+005 | -6.561e+004 | -1.883e+005 | |
| Molar Entropy [kJ/kgmole-C] | 169.6 | 185.1 | 178.2 | |
| Heat Flow [kJ/h] | -1.330e+009 | -1.302e+008 | -1.460e+009 | |

At the bottom, there are 'Delete', 'OK', and 'Ignored' buttons.

Figure 8.19: MIX-101 Worksheet

MIX-102

Boiler Flue Gas and Primary Flue Gas are mixed together in MIX-102 to produce Combine Flue Gas.




Figure 8.20: MIX-102 Design

| | B FG to Mixer | P FG to Mixer | Combine FG |
|-------------------------------|---------------|---------------|-------------|
| Name | B FG to Mixer | P FG to Mixer | Combine FG |
| Vapour | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 584.0 | 690.6 | 666.5 |
| Pressure [kPa] | 1.100e+004 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 2669 | 9040 | 1.171e+004 |
| Mass Flow [kg/h] | 7.481e+004 | 2.530e+005 | 3.278e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 89.43 | 302.9 | 392.4 |
| Molar Enthalpy [kJ/kgmole] | -5.715e+004 | -5.646e+004 | -5.662e+004 |
| Molar Entropy [kJ/kgmole-C] | 156.6 | 161.1 | 160.1 |
| Heat Flow [kJ/h] | -1.526e+008 | -5.104e+008 | -6.630e+008 |

Figure 8.21: MIX-102 Worksheet

8.1.6 Heat Exchangers

Now exchangers are simulated in HYSYS.

Exchanger E 201

In this exchanger, Process Gas is heated using Primary Reformer Flue Gas.




Figure 8.22: Exchanger E 201 Design

| Name | Process Gas | Process Gas to Pri | P FG from Reform | P FG to E 202 A |
|-------------------------------|-------------|--------------------|------------------|-----------------|
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 385.6 | 532.0 | 990.0 | 843.4 |
| Pressure [kPa] | 3808 | 3465 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 7754 | 7754 | 9040 | 9040 |
| Mass Flow [kg/h] | 1.432e+005 | 1.432e+005 | 2.530e+005 | 2.530e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 201.5 | 201.5 | 302.9 | 302.9 |
| Molar Enthalpy [kJ/kgmole] | -1.883e+005 | -1.819e+005 | -4.538e+004 | -5.087e+004 |
| Molar Entropy [kJ/kgmole-C] | 178.2 | 187.8 | 171.1 | 166.5 |
| Heat Flow [kJ/h] | -1.460e+009 | -1.411e+009 | -4.102e+008 | -4.598e+008 |

Figure 8.23: Exchanger E 201 Worksheet

Exchanger E 202 A

In this exchanger, Process Air is heated using Primary Reformer Flue Gas.




Figure 8.24: Exchanger E 202 A Design

Heat Exchanger: E 202 A

| Worksheet | Performance | Dynamics | Rigorous Shell&Tube | |
|-------------------------------|------------------------|--------------------|---------------------|---------------|
| Name | Process Air to E 202 A | Process Air to Sec | P FG to E 202 A | P FG to E 203 |
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 300.0 | 492.0 | 843.4 | 814.8 |
| Pressure [kPa] | 32.40 | 32.40 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1585 | 1585 | 9040 | 9040 |
| Mass Flow [kg/h] | 4.581e+004 | 4.581e+004 | 2.530e+005 | 2.530e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 52.64 | 52.64 | 302.9 | 302.9 |
| Molar Enthalpy [kJ/kgmole] | 6834 | 1.285e+004 | -5.087e+004 | -5.192e+004 |
| Molar Entropy [kJ/kgmole-C] | 181.3 | 190.3 | 166.5 | 165.5 |
| Heat Flow [kJ/h] | 1.083e+007 | 2.036e+007 | -4.598e+008 | -4.694e+008 |

Figure 8.25: Exchanger E 202 A Worksheet

Exchanger E 203

In this exchanger, Steam from steam drum is heated using Primary Reformer Flue Gas.




Figure 8.26: Exchanger E 203 Design

| | From Steam Drum | Steam to F 202 A | P FG to E 203 | P FG to E 204 A |
|-------------------------------|-----------------|------------------|---------------|-----------------|
| Name | Vapour | | | |
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 319.0 | 348.0 | 814.8 | 736.5 |
| Pressure [kPa] | 1.108e+004 | 1.108e+004 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1.418e+004 | 1.418e+004 | 9040 | 9040 |
| Mass Flow [kg/h] | 2.554e+005 | 2.554e+005 | 2.530e+005 | 2.530e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 255.9 | 255.9 | 302.9 | 302.9 |
| Molar Enthalpy [kJ/kgmole] | -2.368e+005 | -2.350e+005 | -5.192e+004 | -5.479e+004 |
| Molar Entropy [kJ/kgmole-C] | 151.9 | 155.0 | 165.5 | 162.8 |
| Heat Flow [kJ/h] | -3.357e+009 | -3.331e+009 | -4.694e+008 | -4.953e+008 |

Figure 8.27: Exchanger E 203 Worksheet

Exchanger E 204 A

In this exchanger, Natural and Recycle gas is heated using Primary Reformer Flue Gas.




Figure 8.28: Exchanger E 204 A Design

Heat Exchanger: E 204 A

| | NG to E 204 A | To Desulphurizer | P FG to E 204 A | P FG to Mixer |
|-------------------------------|---------------|------------------|-----------------|---------------|
| Name | NG to E 204 A | To Desulphurizer | P FG to E 204 A | P FG to Mixer |
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 260.0 | 418.0 | 736.5 | 690.6 |
| Pressure [kPa] | 3906 | 3808 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1984 | 1984 | 9040 | 9040 |
| Mass Flow [kg/h] | 3.924e+004 | 3.924e+004 | 2.530e+005 | 2.530e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 97.39 | 97.39 | 302.9 | 302.9 |
| Molar Enthalpy [kJ/kgmole] | -7.296e+004 | -6.535e+004 | -5.479e+004 | -5.646e+004 |
| Molar Entropy [kJ/kgmole-C] | 172.8 | 185.5 | 162.8 | 161.1 |
| Heat Flow [kJ/h] | -1.447e+008 | -1.297e+008 | -4.953e+008 | -5.104e+008 |

Figure 8.29: Exchanger E 204 A Worksheet

Exchanger F 202 A

In this exchanger, Steam from Steam Drum is heated using Boiler Reformer Flue Gas.




Figure 8.30: Exchanger F 202 A Design

Heat Exchanger: F 202 A

| | Steam to F 202 A | Steam to Boiler | B FG to F 202 A | B FG to Mixer |
|-------------------------------|------------------|-----------------|-----------------|---------------|
| Name | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Vapour | 348.0 | 375.0 | 805.0 | 584.0 |
| Temperature [C] | 1.108e+004 | 1.108e+004 | 1.100e+004 | 1.100e+004 |
| Pressure [kPa] | 1.418e+004 | 1.418e+004 | 2669 | 2669 |
| Molar Flow [kgmole/h] | 2.554e+005 | 2.554e+005 | 7.481e+004 | 7.481e+004 |
| Mass Flow [kg/h] | 255.9 | 255.9 | 89.43 | 89.43 |
| Std Ideal Liq Vol Flow [m3/h] | -2.350e+005 | -2.335e+005 | -4.916e+004 | -5.715e+004 |
| Molar Enthalpy [kJ/kgmole] | 155.0 | 157.3 | 164.8 | 156.6 |
| Molar Entropy [kJ/kgmole-C] | -3.331e+009 | -3.310e+009 | -1.312e+008 | -1.526e+008 |
| Heat Flow [kJ/h] | | | | |

Figure 8.31: Exchanger F 202 A Worksheet

Exchanger E 205

In this exchanger, High Pressure Steam Generator is installed for cooling Combine Flue Gas.




Figure 8.32: Exchanger E 205 Design

| Worksheet | Name | Combine FG | C FG to E 202 A | Q-Steam General |
|-------------|-------------------------------|-------------|-----------------|-----------------|
| Conditions | Vapour | 1.0000 | 1.0000 | <empty> |
| Properties | Temperature [C] | 666.5 | 336.0 | <empty> |
| Composition | Pressure [kPa] | 1.100e+004 | 1.100e+004 | <empty> |
| PF Specs | Molar Flow [kgmole/h] | 1.171e+004 | 1.171e+004 | <empty> |
| | Mass Flow [kg/h] | 3.278e+005 | 3.278e+005 | 8.073e+004 |
| | Std Ideal Liq Vol Flow [m3/h] | 392.4 | 392.4 | <empty> |
| | Molar Enthalpy [kJ/kgmole] | -5.662e+004 | -6.836e+004 | <empty> |
| | Molar Entropy [kJ/kgmole-C] | 160.1 | 144.7 | <empty> |
| | Heat Flow [kJ/h] | -6.630e+008 | -8.005e+008 | 1.375e+008 |

Figure 8.33: Exchanger E 205 Worksheet

Exchanger E 202 B

In this exchanger, Process Air is heated using Combine Flue Gas.




Figure 8.34: Exchanger E 202 B Design

| Name | Process Air | Process Air to E 202 B | C FG to E 202 A | C FG to E 204 B |
|-------------------------------|-------------|------------------------|-----------------|-----------------|
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 177.0 | 300.0 | 336.0 | 321.7 |
| Pressure [kPa] | 32.40 | 32.40 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1585 | 1585 | 1.171e+004 | 1.171e+004 |
| Mass Flow [kg/h] | 4.581e+004 | 4.581e+004 | 3.278e+005 | 3.278e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 52.64 | 52.64 | 392.4 | 392.4 |
| Molar Enthalpy [kJ/kgmole] | 3093 | 6834 | -6.836e+004 | -6.887e+004 |
| Molar Entropy [kJ/kgmole-C] | 173.9 | 181.3 | 144.7 | 143.9 |
| Heat Flow [kJ/h] | 4.901e+006 | 1.083e+007 | -8.005e+008 | -8.064e+008 |

Figure 8.35: Exchanger E 202 B Worksheet

Exchanger E 204 B

In this exchanger, Natural and Recycle gas is heated using Combine Flue Gas.




Figure 8.36: Exchanger E 204 B Design

| Name | Natural+Recycle Gas | NG to E 204 A | C FG to E 204 B | C FG to E 206 |
|-------------------------------|---------------------|---------------|-----------------|---------------|
| Vapour | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 40.97 | 260.0 | 321.7 | 279.0 |
| Pressure [kPa] | 3906 | 3906 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1984 | 1984 | 1.171e+004 | 1.171e+004 |
| Mass Flow [kg/h] | 3.924e+004 | 3.924e+004 | 3.278e+005 | 3.278e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 97.39 | 97.39 | 392.4 | 392.4 |
| Molar Enthalpy [kJ/kgmole] | -8.193e+004 | -7.296e+004 | -6.887e+004 | -7.039e+004 |
| Molar Entropy [kJ/kgmole-C] | 151.3 | 172.8 | 143.9 | 141.2 |
| Heat Flow [kJ/h] | -1.625e+008 | -1.447e+008 | -8.064e+008 | -8.242e+008 |

Figure 8.37: Exchanger E 204 B Worksheet

Exchanger E 206

In this exchanger, Boiler Feed Water is heated using Combine Flue Gas.




Figure 8.38: Exchanger E 206 Design

Heat Exchanger: E 206

Worksheet Performance Dynamics Rigorous Shell&Tube

| Name | BFW | BFW from E 206 | C FG to E 206 | Stack Gas |
|-------------------------------|-------------|----------------|---------------|-------------|
| Vapour | 0.0000 | 0.0000 | 1.0000 | 1.0000 |
| Temperature [C] | 110.0 | 136.0 | 279.0 | 209.0 |
| Pressure [kPa] | 1.383e+004 | 1.383e+004 | 1.100e+004 | 1.100e+004 |
| Molar Flow [kgmole/h] | 1.432e+004 | 1.432e+004 | 1.171e+004 | 1.171e+004 |
| Mass Flow [kg/h] | 2.580e+005 | 2.580e+005 | 3.278e+005 | 3.278e+005 |
| Std Ideal Liq Vol Flow [m3/h] | 258.5 | 258.5 | 392.4 | 392.4 |
| Molar Enthalpy [kJ/kgmole] | -2.794e+005 | -2.773e+005 | -7.039e+004 | -7.292e+004 |
| Molar Entropy [kJ/kgmole-C] | 73.05 | 78.28 | 141.2 | 136.3 |
| Heat Flow [kJ/h] | -4.000e+009 | -3.971e+009 | -8.242e+008 | -8.539e+008 |

Figure 8.39: Exchanger E 206 Worksheet

8.1.7 Product Streams

Following are the heated product streams.

Process Gas to Primary Reformer

Material Stream: Process Gas to Primary Reformer

| Worksheet | Stream Name | Process Gas to Prima | Vapour Phase |
|-------------------|-------------------------------|----------------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 532.0 | 532.0 |
| Composition | Pressure [kPa] | 3465 | 3465 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 7754 | 7754 |
| Petroleum Assay | Mass Flow [kg/h] | 1.432e+005 | 1.432e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 201.5 | 201.5 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -1.819e+005 | -1.819e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 187.8 | 187.8 |
| Cost Parameters | Heat Flow [kJ/h] | -1.411e+009 | -1.411e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 189.0 | 189.0 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.40: Process Gas to Primary Reformer

Process Air to Secondary Reformer

Material Stream: Process Air to Sec Reformer

| Worksheet | Stream Name | Process Air to Sec Re: | Vapour Phase |
|-------------------|-------------------------------|------------------------|--------------|
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 492.0 | 492.0 |
| Composition | Pressure [kPa] | 32.40 | 32.40 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1585 | 1585 |
| Petroleum Assay | Mass Flow [kg/h] | 4.581e+004 | 4.581e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 52.64 | 52.64 |
| User Variables | Molar Enthalpy [kJ/kgmole] | 1.285e+004 | 1.285e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 190.3 | 190.3 |
| Cost Parameters | Heat Flow [kJ/h] | 2.036e+007 | 2.036e+007 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 3.744e+004 | 3.744e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.41: Process Air to Secondary Reformer

Steam to Boiler

Material Stream: Steam to Boiler

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|-----------------|--------------|
| Worksheet | Stream Name | Steam to Boiler | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 375.0 | 375.0 |
| Composition | Pressure [kPa] | 1.108e+004 | 1.108e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.418e+004 | 1.418e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 2.554e+005 | 2.554e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 255.9 | 255.9 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -2.335e+005 | -2.335e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 157.3 | 157.3 |
| Cost Parameters | Heat Flow [kJ/h] | -3.310e+009 | -3.310e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 251.7 | 251.7 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.42: Steam to Boiler

Natural and Recycle Gas to Desulphurizer

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|------------------|--------------|
| Worksheet | Stream Name | To Desulphurizer | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 418.0 | 418.0 |
| Composition | Pressure [kPa] | 3808 | 3808 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1984 | 1984 |
| Petroleum Assay | Mass Flow [kg/h] | 3.924e+004 | 3.924e+004 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 97.39 | 97.39 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -6.535e+004 | -6.535e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 185.5 | 185.5 |
| Cost Parameters | Heat Flow [kJ/h] | -1.297e+008 | -1.297e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 4.681e+004 | 4.681e+004 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay

Figure 8.43: Natural & Recycle Gas to Desulphurizer

Boiler Feed Water Outlet

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|----------------|---------------|
| Worksheet | Stream Name | BFW from E 206 | Aqueous Phase |
| Conditions | Vapour / Phase Fraction | 0.0000 | 1.0000 |
| Properties | Temperature [C] | 136.0 | 136.0 |
| Composition | Pressure [kPa] | 1.383e+004 | 1.383e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.432e+004 | 1.432e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 2.580e+005 | 2.580e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 258.5 | 258.5 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -2.773e+005 | -2.773e+005 |
| Notes | Molar Entropy [kJ/kgmole-C] | 78.28 | 78.28 |
| Cost Parameters | Heat Flow [kJ/h] | -3.971e+009 | -3.971e+009 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 254.2 | 254.2 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay ← →

Figure 8.44: Boiler Feed Water Outlet

Stack Gas

| Worksheet Attachments Dynamics | | | |
|--------------------------------|-------------------------------|-------------|--------------|
| Worksheet | Stream Name | Stack Gas | Vapour Phase |
| Conditions | Vapour / Phase Fraction | 1.0000 | 1.0000 |
| Properties | Temperature [C] | 209.0 | 209.0 |
| Composition | Pressure [kPa] | 1.100e+004 | 1.100e+004 |
| Oil & Gas Feed | Molar Flow [kgmole/h] | 1.171e+004 | 1.171e+004 |
| Petroleum Assay | Mass Flow [kg/h] | 3.278e+005 | 3.278e+005 |
| K Value | Std Ideal Liq Vol Flow [m3/h] | 392.4 | 392.4 |
| User Variables | Molar Enthalpy [kJ/kgmole] | -7.292e+004 | -7.292e+004 |
| Notes | Molar Entropy [kJ/kgmole-C] | 136.3 | 136.3 |
| Cost Parameters | Heat Flow [kJ/h] | -8.539e+008 | -8.539e+008 |
| Normalized Yields | Liq Vol Flow @Std Cond [m3/h] | 2.759e+005 | 2.759e+005 |
| | Fluid Package | Basis-1 | |
| | Utility Type | | |

OK

Delete Define from Stream... View Assay ← →

Figure 8.45: Stack Gas

8.1.6 Higher Pressure Steam Generation

Following is the production rate of steam in E 205 simulated in Aspen HYSYS.




Figure 8.46: High Pressure Generation

8.2 Results

The temperature of stack gas calculated using Aspen Energy Analyzer was 201°C. However, temperature of stack gas simulated on Aspen HYSYS is 209°C. Slight difference in results can be due to fluid package selected or pressure drop factors. Results are significantly close and proposed modifications are supported by Aspen HYSYS simulation.

Chapter 9

HAZOP Analysis

HAZOP analysis is used as a fragment of a Quantitative Risk Assessment. The aim is to investigate the divergence of the plant, from the design intent and formulate risk for workforce and equipment and operability complications.

9.1 Why HAZOP?

The motives for carrying out this study, are primarily, to identify hazards, and to resolve them.

The following Guidewords along with the meanings are illustrated below.

| Guidewords | Meaning |
|-------------------|--|
| NO | Complete negation of the design intent |
| MORE | Quantitative Increase |
| LESS | Quantitative Decrease |
| REVERSE | Logical opposite of the design intent |
| INSTEAD | Complete substitution |

Table 9-1: Guide Words for HAZOP

9.2 Analysis

HAZOP Analysis is done on the major equipment used in convective section of primary reformer.

9.2.1 Valve

Equipment: Valve

Purpose: To control the flow of inlet streams in the reformer

| Parameter | Deviation | Causes | Consequences | Action |
|-----------|-----------|----------------------------|-------------------------------|------------------------------|
| Flow | More | Control Valve fails open | Low heat recovery | Installation of Flow sensors |
| Flow | No | Control Valve fails closed | No heat exchanges in the coil | Replace or clean valve |

Table 9-2: HAZOP Study on Valve

9.2.2 Coils

Equipment: Coils

Purpose: To exchanges heat with Flue gas

| Parameter | Deviation | Causes | Consequences | Action |
|-----------------------|------------------|--|---|---|
| Flow | No | Control Valve fails to open | No heat exchanges in coils | Install temperature sensors |
| Flow | More | Failure of valve to be close | Output temperature too low | Install temperature sensors before and after process streams |
| Flow | Less | Pipe leakage | Temperature of process steam is low | Install flow sensors |
| Flow | Reverse | Failure of process fluid inlet valve | Product offset | Installation of check valve |
| Contamination | high | Poor separation | Low heat recovery | Proper maintenance |
| Pressure (shell side) | low | Inlet pump failed to work properly | No significant variation | Installation of pressure sensors |
| Pressure (shell side) | high | Exchanger outlet discharge valve fails to open | Exchanger shell side will be over pressurized | High pressure security must be installed on shell outlet which if actuated will close all valves. |

Table 9-3: HAZOP Study of Coils

9.2.3 Boiler

Equipment: Boiler

Purpose: To produce steam

| Parameter | Deviation | Causes | Consequences | Action |
|------------------|------------------|--------------------------------------|---|-----------------------------|
| Flow | Low | Failure of inlet control valve | Boiler heated the reactants to high temperature than required | Install flow sensors |
| Flow | High | Inlet valve opens | Poor heating of reactants | Install Control valves |
| Temperature | High | Failure of temperature control valve | Chances of explosion | Install temperature sensors |
| Temperature | low | High flow rate of inlet streams | Low temperature of process streams | Install Control Valves |

Table 9-4: HAZOP Study on Boiler

Chapter 10

Conclusion

By using pinch analysis, not only the source of heat wastage was identified, that is high temperature flue gas being released into environment, but also it suggested away to recover waste heat. Hence led to better heat integration. Around 7% more steam can be produced and stack temperature of the flue gas can be reduced by 19°C using proposed heat exchanger network design. Proposed design also achieves 91.5% of the area target calculated using Bath Algorithm.

Economic analysis shows the payback period after applying these modifications is just 2.06 years with the cost saving of 0.45 million dollars per year. Due to reduction in stack temperature of flue gases, environmental impact is also reduced.

References

1

Kemp, I. C. (2011). Pinch Analysis and Process Integration: A User Guide on Process Integration for the Efficient Use of Energy. Elsevier.

2

Gundersen, T. (2002). What is Process Integration? International Energy Agency: International Collaboration in Energy Technology: A Sampling of Success Stories.

3

Tjoe TN, L. B. (1986). Using Pinch Technology for Process Retrofit. Chem Eng, 47-60.

4

Panjeshahi, M. H. (2008). Retrofit of Ammonia Plant for Improving Energy Efficiency. Energy, 46-64.

5

Sinnott, R. K. (2005). Coulson & Richardson's Chemical Engineering: Vol. 6. Oxford: Elsevier Butterworth-Heinemann.

6

Wang Y, D. J. (2003). Application of Total Process Energy-Integration in Retrofitting an Ammonia Plant. Appl Energy, 467-547.

7

Aspen Technology, Inc. (2015). Aspen Energy Analyzer: User Guide. Bedford, MA.

8

Rennie, T. J. (2006). Numerical Studies of a Double-pipe Helical Heat Exchanger. Applied Thermal Engineering, 1266-1273.